



City of Meridian, Mississippi
List of SSOs from September 2008 to May 6, 2014

Date SSO Event Report Received by MDEQ	SSO Reporting		City Notified of SSO Event			SSO Ceased		Location of SSO		Ultimate Destination of SSO	Volume of SSO, (gal) (approx.)	Cause of SSO	Corrective Actions to Stop SSO	Corrective Action to Prevent Future SSOs	Miscellaneous Information
	City of Meridian Excel Matrix	MDEQ Excel Matrix	Time		Date	Time	Date	Location	Source						
1/12/2009			NOT AVAILABLE		12/29/2008	NOT AVAILABLE	1/12/2009	SOUTH WWTP	EQ BASINS	SOWASHEE CREEK	15,000,000	DUE TO CONTINUOUS RAINY DAYS, PLANT REACHED MAXIMUM TREATMENT CAPACITY SO EXCESS WAS DIVERTED TO EQ BASINS	ONCE THE INCLEMENT WEATHER SUBSIDED, INFLUENT FLOW DECREASED AND PLANT CEASED BYPASSING TO EQ BASINS	PLAN TO REPLACE FLEXIBLE CURTAIN IN BASIN AND DREDGING OF SOLIDS FROM WITHIN BASIN TO INCREASE CAPACITY	RECORDED FROM NPDES EXCEEDANCE LETTER TO MDEQ
3/20/2009	✓		6AM		3/16/2009	4PM	3/16/2009	HAMILTON AVENUE	MANHOLE	SOWASHEE CREEK	6,500	POWER OUTAGE AT WASTEWATER TREATMENT PLANT & RAINFALL OF 2 INCHES	MS POWER HAD ELECTRICAL COMPONENTS SHIPPED OVERNIGHT TO CORRECT PROBLEM	PARTS INSTALLED BY MS POWER	
3/23/2009	✓		3PM		3/18/2009	6PM	3/20/2009	WEST OF 29TH AVENUE & NORTH OF ST. PAUL STREET, IN THE WOODS	HOLE IN PIPE	SOWASHEE CREEK	12,000	HOLE IN PIPE, COLLAPSED PIPE	DEBRIS REMOVED FROM PIPE WITH FLUSH TRUCK, CHLORINE TABLETS ADDED TO OVERFLOW	COLLAPSED PIPE REPAIRED	
5/4/2009	✓		NOT AVAILABLE		3/16/2009	NOT AVAILABLE	4/7/2009	SOWASHEE STREET	MANHOLE	SOWASHEE CREEK	160,000	I&I, FAILURE OF PIPE DOWN STREET THAT BLOCKED & RESTRICTED FLOW - 4.5 INCHES OF RAINFALL	MISCELLANEOUS LINE REPAIRS ON 24" PIPE. CREW CLEANED UP DEBRIS AND LIME WAS SPREAD OVER ENTIRE AREA	PLAN TO UPGRADE 24" LINE TO 36" LINE TO PREVENT FUTURE SSOs.	CITY OF MERIDIAN BYPASS REPORT INCLUDED SUPPLEMENTAL REPORT OF EVENT
INFO NOT AVAILABLE	✓		10:30AM		5/15/2009	2PM	5/15/2009	HAMILTON AVENUE	MANHOLE	SOWASHEE CREEK	85,000	EXCESSIVE RAINFALL - 3.5 INCHES TO 4 INCHES	DEBRIS REMOVED AND DISINFECTED AREA	NO INFORMATION PROVIDED	
1/8/2010			NOT AVAILABLE		12/17/2009	NOT AVAILABLE	1/8/2010	SOUTH WWTP	EQ BASINS	SOWASHEE CREEK	19,430,000	DUE TO CONTINUOUS RAINY DAYS AND PORTION OF MAIN PLANT BEING OFFLINE, PLANT WAS FORCED TO DIVERTED PORTION OF NORMAL FLOW	ONCE PORTION OF MAIN PLANT WAS BROUGHT BACK ONLINE, PLANT CEASED BYPASSING TO EQ BASINS	PLAN TO REPLACE FLEXIBLE CURTAIN IN BASIN AND DREDGING OF SOLIDS FROM WITHIN BASIN TO INCREASE CAPACITY	RECORDED FROM NPDES EXCEEDANCE LETTER TO MDEQ
1/14/2010	✓		10:30AM		12/18/2009	2PM	12/21/2009	HAMILTON AVENUE	MANHOLE	SOWASHEE CREEK	170,000	EXCESSIVE RAINFALL - 3.5 INCHES TO 4 INCHES	NO INFORMATION PROVIDED	NO INFORMATION PROVIDED	
1/19/2010	✓		12PM		1/13/2010	10AM	1/14/2010	FRED CLAYTON ROAD	PRESSURE LINE	LOST HORSE CREEK	290,000	BROKEN LINE	REPAIRED LINE	REPAIRED LINE	
1/24/2010	✓		NOT AVAILABLE		2/21/2010	NOT AVAILABLE	2/24/2010	4001 NEWELL ROAD	MANHOLE	SOWASHEE CREEK	170,000	GREASE AND ROOTS IN MANHOLE, 3+ INCHES OF RAIN AND 4 INCHES OF SNOW	FLUSHED LINE	CLEANED ROOTS FROM MANHOLE AND REPAIRED PIPE	
2/22/2010			NOT AVAILABLE		FEB. 2010	NOT AVAILABLE	2/22/2010	SOUTH WWTP	EQ BASINS	SOWASHEE CREEK	21,000,000	PART OF MAIN PLANT OFFLINE DUE TO PUMP REPAIRS, RESULTING IN DIVERSION TO EQ BASINS	ONCE PORTION OF MAIN PLANT BROUGHT BACK ONLINE FOLLOWING INSTALLATION OF NEW MOTOR ON PRIMARY SLUDGE PUMPS	PLAN TO REPLACE FLEXIBLE CURTAIN IN BASIN AND DREDGING OF SOLIDS FROM WITHIN BASIN TO INCREASE CAPACITY	RECORDED FROM NPDES EXCEEDANCE LETTER TO MDEQ
3/15/2010	✓		MIDNIGHT		3/10/2010	NOT AVAILABLE	NOT AVAILABLE	SOWASHEE STREET	MANHOLE	SOWASHEE CREEK	75,000	EXCESSIVE RAINFALL - 2+ INCHES	CITY CREWS WORKING ON PROBLEM AT CHIP MILL	PLANS ARE BEING PUT IN PLACE TO INCREASE CAPACITY IN LINE	
3/15/2010	✓		2:33PM		3/12/2010	7PM	3/15/2010	HWY 45 & HWY 39	RAISED MANHOLE	SOWASHEE CREEK	200,000	HIGH RAINFALL & MANHOLE INFILTRATION	REPAIR MANHOLE	CITY CREWS WORKING ON CHIPMILL PROBLEM	
3/23/2010	✓		MIDNIGHT		3/10/2010	9:45AM	3/16/2010	SOWASHEE STREET	MANHOLE	SOWASHEE CREEK	95,000	EXCESSIVE RAINFALL - 2+ INCHES	CITY CREWS WORKING ON PROBLEM AT CHIP MILL	PLANS ARE BEING PUT IN PLACE TO INCREASE CAPACITY IN LINE	
3/24/2010			11AM		3/24/2010	2PM	3/24/2010	SOWASHEE STREET (BEHIND MISSISSIPPI MUSIC)	MANHOLE	TRIBUTARY OF SOWASHEE CREEK	NO INFORMATION AVAILABLE	NO INFORMATION AVAILABLE	CITY CREWS COLLECTED DEBRIS, EXCAVATED AFFECTED SOIL, AND LIMED IMPACTED AREA	NO INFORMATION PROVIDED	INFORMATION RECORDED FROM MARCH 25, 2010 MEMORANDUM FROM MDEQ

Date SSO Event Report Received by MDEQ	SSO Reporting		City Notified of SSO Event			SSO Ceased		Location of SSO		Ultimate Destination of SSO	Volume of SSO, (gal) (approx.)	Cause of SSO	Corrective Actions to Stop SSO	Corrective Action to Prevent Future SSOs	Miscellaneous Information
	City of Meridian Excel Matrix	MDEQ Excel Matrix	Time		Date	Time	Date	Location	Source						
MAR. 2010			NOT AVAILABLE		MAR. 2010	NOT AVAILABLE	MAR. 2010	SOUTH WWTP	EQ BASINS	SOWASHEE CREEK	51,050,000	DUE TO CONTINUOUS RAINY DAYS AND PORTION OF MAIN PLANT BEING OFFLINE, PLANT WAS FORCED TO DIVERTED PORTION OF FLOW TO EQ BASINS	ONCE PORTION OF MAIN PLANT WAS BROUGHT BACK ONLINE, PLANT CEASED BYPASSING TO EQ BASINS	PLAN TO REPLACE FLEXIBLE CURTAIN IN BASIN AND DREDGING OF SOLIDS FROM WITHIN BASIN TO INCREASE CAPACITY	
11/24/2010	✓	✓	7AM		11/24/2010	10:30AM	11/24/2010	26TH STREET/2606 EDGEWOOD DRIVE	MANHOLE	SOWASHEE CREEK	80,000	ROOTS IN MANHOLE	FLUSH TRUCK 'SHOT LINE' & OPEN IT	CREW CUT ROOTS OUT OF MANHOLE	FULL REPORT INCLUDES PICTURES
1/13/2011	✓		3AM		1/7/2011	8AM	1/7/2011	3900 OLD HWY 45 N.	MANHOLE	UNSPECIFIED	40,000	POWER FAILURE AT PLANT	RESET MAIN POWER BREAKER	NEW GROUND TO BLOWER MOTOR	
2/10/2011	✓	✓	NOT AVAILABLE		1/31/2011	NOT AVAILABLE	2/10/2011	HILLCREST DRIVE/BROADHEAD PROPERTY	MANHOLE	UNSPECIFIED	25,000	TREE ROOTS	SPREAD LIME OVER AREA	PLANS TO REPLACE MANHOLE & REMOVE TREE THIS WEEK - WEATHER PERMITTING	FULL REPORT INCLUDES PICTURES
2/15/2011	✓		1PM		2/11/2011	9AM	2/14/2011	HYUNDAI HWY 39	MANHOLE	SOWASHEE CREEK	4,000	GREASE IN MANHOLE	FLUSHED LINES	RED HOT COMPOUND USED TO CLEAN LINE	
2/17/2011	✓		10:30AM		2/17/2011	11:30AM	2/17/2011	SHUMATE ROAD	MANHOLE	UNSPECIFIED	300	GREASE BLOCKAGE	FLUSHED LINES, RED HOT COMPOUND USED TO CLEAN LINE	LOCATION ADDED TO A BI-WEEKLY FLUSHING SCHEDULE	
3/10/2011	✓	✓	10PM ON SSO, 2AM CITY		3/8/2011	2AM	3/9/2011	SOWASHEE STREET	MANHOLE	SOWASHEE CREEK	8,400	EXCESSIVE RAINFALL - 6 INCHES	COLLECTED DEBRIS AND DISINFECTED AREA	NO INFORMATION PROVIDED	
3/10/2011	✓	✓	8PM		3/8/2011	6PM	3/10/2011	HWY 11/80 & RUSSELL DRIVE ON 8 INCH LINE THAT CONNECTS TO A 24 INCH LINE, BEHIND STRIBLING EQUIPMENT	MANHOLE	SOWASHEE CREEK	229,950	EXCESSIVE RAINFALL - 6 INCHES	COLLECTED DEBRIS AND DISINFECTED AREA	NO INFORMATION PROVIDED	
3/10/2011	✓	✓	8PM		3/8/2011	6PM	3/10/2011	HWY 11/80 AT CRACKER BARREL	MANHOLE	SOWASHEE CREEK	65,000	EXCESSIVE RAINFALL - 6 INCHES	COLLECTED DEBRIS AND DISINFECTED AREA	NO INFORMATION PROVIDED	
3/24/2011			NOT AVAILABLE		3/11/2011	NOT AVAILABLE	3/11/2011	SOUTH WWTP	EQ BASINS	SOWASHEE CREEK	9,800,000	PLANT WAS FORCED TO DIVERTED PORTION OF FLOW TO EQ BASINS	ONCE INFLUENT FLOW DECREASED, PLANT CEASED BYPASSING TO EQ BASINS	PLAN TO REPLACE FLEXIBLE CURTAIN IN BASIN AND DREDGING OF SOLIDS FROM WITHIN BASIN TO INCREASE CAPACITY	
4/6/2011	✓		4AM		4/4/2011	7:30AM	4/4/2011	3900 OLD HWY 45 S.	INFLUENT LIFT STATION	UNSPECIFIED	25,000	POWER FAILURE	RESET MAIN POWER BREAKER	ADJUSTED ELECTRICAL PANEL AND GROUND FAULT SENSORS	
4/29/2011	✓	✓	5PM		4/28/2011	8PM	4/28/2011	HWY 11/80 AT STRIBLING EQUIPMENT	MANHOLE	SOWASHEE CREEK	225	I&I, 3 INCHES OF RAIN, AS WELL AS PREVIOUS RAIN IN PAST 2 WEEKS	NO INFORMATION PROVIDED	NO INFORMATION PROVIDED	
7/14/2011	✓	✓	2PM		6/16/2011	2PM	7/6/2011	15TH PLACE	MANHOLE	SOWASHEE CREEK	250,000	COMBINATION OF ROOTS & GREASE, A COLLAPSED LINE	JETTED & BROKE THE BLOCKAGE, REPLACED DAMAGED LINE	REPLACED LINE	NOTIFIED OF BAD SEWER ODOR ON JULY 5, 2011
7/26/2011	✓		2PM		7/25/2011	5PM	7/25/2011	HWY 11/80 CRACKER BARREL	MANHOLE	SOWASHEE CREEK	1,800	HIGH RAINFALL OF 1.5 INCHES	CLEANED DEBRIS AND SANITIZED	NO INFORMATION PROVIDED	
7/26/2011	✓		2PM		7/25/2011	5PM	7/25/2011	SOWASHEE STREET	MANHOLE	SOWASHEE CREEK	2,700	HIGH RAINFALL OF 1.5 INCHES	NO INFORMATION PROVIDED	NO INFORMATION PROVIDED	
7/26/2011	✓	✓	3:30PM		7/25/2011	4:30PM	7/25/2011	56TH AVENUE @ ROYAL ROAD	MANHOLE	GALLAGHER CREEK	1,000	EXCESSIVE RAINFALL - 1 INCH	CLEANED DEBRIS (SMALL AMOUNTS OF PAPER & GREASE) & SPRAYED DISINFECTANT OVER ENTIRE AREA	NO INFORMATION PROVIDED	
11/18/2011	✓	✓	7AM		11/16/2011	1PM	11/16/2011	OLD 8TH STREET & 70TH PLACE	PUMP STATION	SOWASHEE CREEK	12,000	PUMP FAILURE	CLEANED DEBRIS & USED DISINFECTANT TO KILL BACTERIA IN THE AREA	PUMP REPAIRED	FULL REPORT INCLUDES PICTURES
11/21/2011	✓	✓	2:30PM		11/18/2011	10:30PM	11/18/2011	29TH AVENUE, SOUTH BANK, APPROXIMATELY 200 YARDS WEST OF 29TH AVENUE BRIDGE/RR	MANHOLE	SOWASHEE CREEK	48,000	CAVE-IN, STORMWATER DRAIN	DIRT REMOVED TO ALLOW SEWAGE TO FLOW, TRENCH BOX PUT INTO PLACE TO PROTECT THE LINE	LINE WILL BE REPLACED WITH A LARGER LINE	FULL REPORT INCLUDES PICTURES
12/2/2011		✓	10AM		11/30/2011	1AM	12/1/2011	29TH AVENUE @ RR	MAIN LINE	SOWASHEE CREEK	700,000	PUMP FAILURE & SEPARATION IN LINE	SWITCHED OUT PORTABLE PUMP, REPAIRED LINE, LIME WAS SPREAD OVER ENTIRE AREA	REPAIRED LINE AND SWITCHED OUT PUMP	FULL REPORT INCLUDES PICTURES

Date SSO Event Report Received by MDEQ	SSO Reporting		City Notified of SSO Event			SSO Ceased		Location of SSO		Ultimate Destination of SSO	Volume of SSO, (gal) (approx.)	Cause of SSO	Corrective Actions to Stop SSO	Corrective Action to Prevent Future SSOs	Miscellaneous Information
	City of Meridian Excel Matrix	MDEQ Excel Matrix	Time		Date	Time	Date	Location	Source						
1/3/2012	✓	✓	10AM		12/29/2011	2:30PM	12/29/2011	11/80 EAST AT CRACKER BARREL	MANHOLE	SOWASHEE CREEK	5,400	GREASE BLOCKAGE	GREASE REMOVED BY FLUSH TRUCK, DEBRIS COLLECTED & REMOVED, LIME WAS SPREAD OVER ENTIRE AREA	NO INFORMATION PROVIDED	
1/27/2012	✓		10AM		1/26/2012	2PM	1/26/2012	5310 OVERBROOK LANE	MANHOLE	UNSPECIFIED	10 gpm	GREASE BLOCKAGE & INFLOW	JETTED LINE TO BREAK BLOCKAGE & RESUME NORMAL FLOW, DEBRIS COLLECTED & REMOVED, LIME WAS SPREAD OVER ENTIRE AREA	JETTED LINE TO BREAK BLOCKAGE & RESUME NORMAL FLOW	
1/27/2012	✓		10AM		1/26/2012	5PM	1/26/2012	SOWASHEE STREET	MANHOLE	SOWASHEE CREEK	20 gpm	INFLOW - 3 INCHES OF RAIN	DEBRIS COLLECTED & REMOVED, LIME WAS SPREAD OVER ENTIRE AREA	NO INFORMATION PROVIDED	
1/27/2012	✓		10AM		1/26/2012	6PM	1/26/2012	HWY 11/80 EAST AT CRACKER BARREL	MANHOLE	SOWASHEE CREEK	20 gpm	INFLOW - 3 INCHES OF RAIN	DEBRIS COLLECTED & REMOVED, LIME WAS SPREAD OVER ENTIRE AREA	NO INFORMATION PROVIDED	
1/27/2012	✓		9AM		1/26/2012	2PM	1/26/2012	26TH STREET & 40TH AVENUE	MAIN LINE	NO INFORMATION PROVIDED	4,500	INFLOW - 3 INCHES OF RAIN	DEBRIS COLLECTED & REMOVED, LIME WAS SPREAD OVER ENTIRE AREA	NO INFORMATION PROVIDED	
2/3/2012	✓		8AM		1/27/2012	10AM	1/30/2012	3109 GRANDVIEW AVENUE	LINE	SOWASHEE CREEK	15gpm	BROKEN PIPE	REPLACED BROKEN PIPE, LIME WAS SPREAD OVER ENTIRE AREA	REPLACED BROKEN PIPE	
2/3/2012	✓		1PM		1/30/2012	2PM	1/31/2012	5525 CHEROKEE ROAD	MANHOLE	SOWASHEE CREEK	10 gpm	BROKEN PIPE	REPLACED BROKEN PIPE, LIME WAS SPREAD OVER ENTIRE AREA	REPLACED BROKEN PIPE	
2/3/2012	✓		11AM		2/2/2012	6PM	2/2/2012	600 FRONTAGE ROAD	LINE	SOWASHEE CREEK	60 gpm	BROKEN PIPE	REPLACED BROKEN PIPE, LIME WAS SPREAD OVER ENTIRE AREA	REPLACED BROKEN PIPE	
2/3/2012	✓		11AM		2/2/2012	5PM	2/2/2012	2900 SAINT PAUL STREET	LINE	SOWASHEE CREEK	60 gpm	BROKEN PIPE	REPLACED BROKEN PIPE, LIME WAS SPREAD OVER ENTIRE AREA	REPLACED BROKEN PIPE	
3/2/2012	✓		10AM		2/28/2012	6PM	2/28/2012	SOWASHEE STREET	MANHOLE	SOWASHEE CREEK	9,600	INFLOW - 1 INCH OF RAIN	DEBRIS COLLECTED & REMOVED, LIME WAS SPREAD OVER ENTIRE AREA	NO INFORMATION PROVIDED	
3/2/2012	✓		10AM		2/28/2012	8:30AM	2/29/2012	HWY 11/80 EAST AT CRACKER BARREL	MANHOLE	SOWASHEE CREEK	168,750	GREASE BLOCKAGE	GREASE REMOVED BY FLUSH TRUCK, DEBRIS COLLECTED & REMOVED, LIME WAS SPREAD OVER ENTIRE AREA	NO INFORMATION PROVIDED	
3/26/2012			4PM		3/21/2012	7AM	3/24/2012	SOWASHEE STREET	MANHOLE	SOWASHEE CREEK	96,000	EXCESSIVE RAINFALL - 3.5 INCHES	WORK ON PROBLEM AT CHIP MILL	PLANS TO REPLACE OLD SEWER LINE, INCREASE NEW LINE	
3/26/2012			4PM		3/21/2012	7AM	3/24/2012	HWY 11/80 EAST AT CRACKER BARREL	MANHOLE	SOWASHEE CREEK	65,000	EXCESSIVE RAINFALL - 3.5 INCHES	CLEANED UP	PLANS TO INCREASE LINE AT CHIP MILL	
3/26/2012			4PM		3/21/2012	7AM	3/24/2012	HWY 11/80 EAST & RUSSELL STREET, BEHIND STRIBLING EQUIPMENT	MANHOLE	SOWASHEE CREEK	100,000	EXCESSIVE RAINFALL - 3.5 INCHES	NO INFORMATION PROVIDED	PLANS TO INCREASE LINE AT CHIP MILL	
4/2/2012	✓	✓	10:30AM		3/29/2012	11:15AM	3/29/2012	HWY 11/CELOTEX	MANHOLE	SOWASHEE CREEK	600,000	PUMP STATION FAILURE	PUMP WAS RESET, LIME WAS SPREAD OVER THE ENTIRE AREA	PUMP WAS RESET	
6/25/2012		✓	7AM		6/25/2012	8:30AM	6/25/2012	HWY 39, NUMBER 1 LIFT STATION	PUMP STATION	SOWASHEE CREEK	50,000	POWER FAILURE	RESTORED POWER, COLLECTED ALL DEBRIS, SPREAD LIME OVER THE ENTIRE AREA	POWER RESTORED TO PUMP STATION	
8/1/2012	✓	✓	8PM		7/26/2012	8:30AM	7/27/2012	29TH AVENUE	MANHOLE	NONE	35,000	BROKEN LINE	REPAIRED LINE, DEBRIS COLLECTED & REMOVED, LIME WAS SPREAD OVER ENTIRE AREA	REPAIR OF LINE	
8/20/2012		✓	3:30PM		8/18/2012	6PM	NOT AVAILABLE	TOMMY WEBB DRIVE	MANHOLE	SOWASHEE CREEK	200,000	I&I, 2 INCHES OF RAINFALL	NO INFORMATION PROVIDED	NO INFORMATION PROVIDED	
12/17/2012	✓		10AM		12/17/2012	8PM	12/17/2012	CHIP PICKERING DRIVE AND STENNIS DRIVE	PIPE	SOWASHEE CREEK	320,000	BROKEN PIPE	STOPPED PUMP TO CEASE FLOW, REPAIRED PIPE AND SPREAD LIME OVER ENTIRE AREA	REPAIRED PIPE LINE	

Date SSO Event Report Received by MDEQ	SSO Reporting		City Notified of SSO Event			SSO Ceased		Location of SSO		Ultimate Destination of SSO	Volume of SSO, (gal) (approx.)	Cause of SSO	Corrective Actions to Stop SSO	Corrective Action to Prevent Future SSOs	Miscellaneous Information
	City of Meridian Excel Matrix	MDEQ Excel Matrix	Time		Date	Time	Date	Location	Source						
1/4/2013	✓	✓	3:30PM		12/28/2012	NOT AVAILABLE	12/29/2012	HWY 45 SOUTH, BEHIND MS POWER	MANHOLE	SOWASHEE CREEK	350,000	BLOCKAGE	FLUSHED LINE & CLEANED DEBRIS, LIME WAS SPREAD OVER ENTIRE AREA	NO INFORMATION PROVIDED	
1/4/2013	✓	✓	8PM		12/29/2012	11PM	12/29/2012	HWY 11/80 EAST AT CRACKER BARREL	MANHOLE	SOWASHEE CREEK	18,000	EXCESSIVE RAINFALL	DEBRIS COLLECTED & REMOVED, LIME WAS SPREAD OVER ENTIRE AREA	NO INFORMATION PROVIDED	
1/4/2013	✓	✓	8PM		12/30/2012	11PM	12/30/2012	SOWASHEE STREET	MANHOLE	DITCH TO SOWASHEE CREEK	1,800	EXCESSIVE RAINFALL - 1.5 INCHES	DEBRIS COLLECTED & REMOVED, LIME WAS SPREAD OVER ENTIRE AREA	NO INFORMATION PROVIDED	
1/14/2013	✓	✓	7PM		1/12/2013	6AM	1/13/2013	HWY 45 NORTH , EAST MERIDIAN WWTP	MANHOLE	SOWASHEE CREEK	13,200	EXCESSIVE RAINFALL - ABOUT 2 INCHES	COLLECTED DEBRIS AND SPREAD LIME OVER AREA	NO INFORMATION PROVIDED	
1/14/2013	✓	✓	6PM		1/12/2013	NOT AVAILABLE	1/14/2013	HWY 11/80 EAST AT CRACKER BARREL	MANHOLE	SOWASHEE CREEK	72,000	EXCESSIVE RAINFALL - ABOUT 2 INCHES	COLLECTED DEBRIS	NO INFORMATION PROVIDED	ONGOING
1/14/2013	✓	✓	6PM		1/12/2013	6AM	1/13/2013	SOWASHEE STREET	MANHOLE	SOWASHEE CREEK	10,800	EXCESSIVE RAINFALL - 2INCHES	COLLECTED DEBRIS AND SPREAD LIME OVER AREA	NO INFORMATION PROVIDED	
1/28/2013	✓	✓	10AM		1/16/2013	10AM	1/19/2013	SOWASHEE STREET	MANHOLE	SOWASHEE CREEK	51,000	EXCESSIVE RAINFALL - ABOUT 8 INCHES FOR THE MONTH, A COLLAPSED LINE	COLLECTED DEBRIS AND SPREAD LIME OVER AREA	REPAIRED LINE	
1/28/2013	✓	✓	10AM		1/16/2013	8AM	1/17/2013	HWY 11/80, BEHIND STRIBLING EQUIPMENT	MANHOLE	SOWASHEE CREEK	66,000	EXCESSIVE RAINFALL - ABOUT 8 INCHES FOR THE MONTH, A COLLAPSED LINE	SPREAD LIME OVER AREA	REPAIRED LINE	
1/28/2013	✓	✓	10AM		1/16/2013	8AM	1/21/2013	HWY 45 NORTH, EAST MERIDIAN WWTP	MANHOLE	SOWASHEE CREEK	142,000	EXCESSIVE RAINFALL - ABOUT 8 INCHES FOR THE MONTH, A COLLAPSED LINE	COLLECTED DEBRIS AND SPREAD LIME OVER AREA	REPAIRED LINE	
1/28/2013	✓	✓	10AM		1/16/2013	12NOON	1/23/2013	HWY 11/80 EAST AT CRACKER BARREL	MANHOLE	SOWASHEE CREEK	151,200	EXCESSIVE RAINFALL - ABOUT 8 INCHES FOR THE MONTH, A COLLAPSED LINE	COLLECTED DEBRIS AND SPREAD LIME OVER AREA	REPAIRED LINE	
1/28/2013	✓	✓	1PM		1/23/2013	7PM	1/23/2013	29TH AVENUE, MULTI-COUNTY	MAHNOLE	SOWASHEE CREEK	1,500	BLOCKAGE IN SEWER LINE	COLLECTED DEBRIS, SPREAD LIME OVER AREA	NO INFORMATION PROVIDED	
2/1/2013	✓	✓	11AM		1/30/2013	8PM	1/30/2013	HWY 45 NORTH, ENTRANCE TO EAST MERIDIAN WWTP	MANHOLE	SOWASHEE CREEK	8,100	EXCESSIVE RAINFALL - ABOUT 2 INCHES	COLLECTED DEBRIS, SPREAD LIME OVER AREA	NO INFORMATION PROVIDED	
2/1/2013	✓	✓	11AM		1/30/2013	8PM	1/30/2013	SOWASHEE STREET	MANHOLE	SOWASHEE CREEK	2,700	EXCESSIVE RAINFALL - ABOUT 2 INCHES	COLLECTED DEBRIS, SPREAD LIME OVER AREA	NO INFORMATION PROVIDED	
2/1/2013	✓	✓	11AM		1/30/2013	8PM	1/30/2013	HWY 11/80, BEHIND STRIBLING EQUIPMENT	MANHOLE	SOWASHEE CREEK	10,800	EXCESSIVE RAINFALL - ABOUT 2 INCHES	NO INFORMATION PROVIDED	NO INFORMATION PROVIDED	
2/1/2013	✓	✓	11AM		1/30/2013	8PM	1/30/2013	HWY 11/80 AT CRACKER BARREL	MANHOLE	SOWASHEE CREEK	5,400	EXCESSIVE RAINFALL - ABOUT 2 INCHES	NO INFORMATION PROVIDED	NO INFORMATION PROVIDED	
2/11/2013	✓	✓	5PM		2/6/2013	2PM	2/7/2013	CHIP PICKERING DRIVE	MAIN LINE	SOWASHEE CREEK	300,000	BREAK IN LINE	SPREAD LIME OVER AREA	REPAIRED LINE	
2/14/2013	✓		1PM		2/13/2013	10PM	2/13/2013	65TH AVENUE (MAPLE GAS TERMINAL)	MANHOLE	SOWASHEE CREEK	10,800	EXCESSIVE RAINFALL - 6.74 INCHES BETWEEN 2/10/13 TO 2/12/13	NO INFORMATION PROVIDED	NO INFORMATION PROVIDED	
2/14/2013	✓		9AM		2/12/2013	11PM	2/12/2013	40TH AVENUE & 26 STREET	MANHOLE	SOWASHEE CREEK	2,520	EXCESSIVE RAINFALL - 2.9 INCHES 2/11/2013 TO 2/12/3013	COLLECTED DEBRIS AND SPREAD LIME OVER AREA	NO INFORMATION PROVIDED	
2/14/2013	✓		9AM		2/12/2013	11PM	2/12/2013	26 & 41ST STREET	MANHOLE	SOWASHEE CREEK	4,200	EXCESSIVE RAINFALL - 2.9 INCHES 2/11/2013 TO 2/12/3013	COLLECTED DEBRIS AND SPREAD LIME OVER AREA	NO INFORMATION PROVIDED	
2/14/2013	✓		8PM		2/10/2013	NOT AVAILABLE	2/13/2013	HWY 45 NORTH (EAST MERIDIAN WWTP ENTRANCE)	MANHOLE	SOWASHEE CREEK	42,000	EXCESSIVE RAINFALL - 6.74 INCHES BETWEEN 2/10/13 TO 2/12/13	COLLECTED DEBRIS AND SPREAD LIME OVER AREA	NO INFORMATION PROVIDED	
2/14/2013	✓		8PM		2/10/2013	6PM	2/13/2013	HWY 11 & 80 AT CRACKER BARREL	MANHOLE	SOWASHEE CREEK	70,800	EXCESSIVE RAINFALL -6.74 INCHES	COLLECTED DEBRIS AND SPREAD LIME OVER AREA	NO INFORMATION PROVIDED	
2/14/2013	✓		8PM		2/10/2013	6PM	2/13/2013	HWY 11 & 80, BEHIND STRIBLING EQUIPMENT	MANHOLE	SOWASHEE CREEK	84,000	EXCESSIVE RAINFALL - 6.74 INCHES BETWEEN 2/10/13 TO 2/12/13	COLLECTED DEBRIS AND SPREAD LIME OVER AREA	NO INFORMATION PROVIDED	
2/14/2013	✓		6PM		2/11/2013	10PM	2/12/2013	SOWASHEE STREET	MANHOLE	SOWASHEE CREEK	4,800	EXCESSIVE RAINFALL - 2.9 INCHES	COLLECTED DEBRIS AND SPREAD LIME OVER AREA	NO INFORMATION PROVIDED	

Date SSO Event Report Received by MDEQ	SSO Reporting		City Notified of SSO Event			SSO Ceased		Location of SSO		Ultimate Destination of SSO	Volume of SSO, (gal) (approx.)	Cause of SSO	Corrective Actions to Stop SSO	Corrective Action to Prevent Future SSOs	Miscellaneous Information
	City of Meridian Excel Matrix	MDEQ Excel Matrix	Time		Date	Time	Date	Location	Source						
2/14/2013	✓		8PM		2/10/2013	10AM	2/11/2013	SOWASHEE STREET	MANHOLE	SOWASHEE CREEK	4,200	EXCESSIVE RAINFALL - 3.48 INCHES	COLLECTED DEBRIS AND SPREAD LIME OVER AREA	IDENTIFY I&I SPOTS IN LINE AND MAKE SPOT REPAIRS, TWO BREAKS AND ONE MANHOLE HAVE BEEN IDENTIFIED, REPAIRS BEGAN 2/14/2013 ON THESE	
2/14/2013	✓		8PM		2/10/2013	10AM	2/11/2013	HWY 145 & SOWASHEE STREET	MANHOLE	SOWASHEE CREEK	1,680	EXCESSIVE RAINFALL - 3.48 INCHES	COLLECTED DEBRIS AND SPREAD LIME OVER AREA	NO INFORMATION PROVIDED	
2/14/2013	✓		1PM		2/13/2013	2PM	2/13/2013	OLD 8TH STREET	MANHOLE	SOWASHEE CREEK	300	PUMP FAILURE DUE TO RAGS PREVENTING IMPALERS FROM TURNING	COLLECTED DEBRIS AND SPREAD LIME OVER AREA, PULLED PUMP TO BE REPAIRED	REPAIR OF PUMP	
3/19/2013	✓	✓	2PM		3/11/2013	7PM	3/11/2013	HWY 11/80, BEHIND STRIBLING EQUIPMENT	MANHOLE	SOWASHEE CREEK	6,000	EXCESSIVE RAINFALL - 1.5 INCHES	SPREAD LIME OVER AREA	NO INFORMATION PROVIDED	
3/19/2013	✓	✓	2PM		3/11/2013	7PM	3/11/2013	HWY 11/80 AT CRACKER BARREL	MANHOLE	SOWASHEE CREEK	3,000	EXCESSIVE RAINFALL - 1.5 INCHES	COLLECTED DEBRIS AND SPREAD LIME OVER AREA	NO INFORMATION PROVIDED	
3/19/2013	✓	✓	2PM		3/11/2013	7PM	3/11/2013	PARKWAY BOULEVARD	MANHOLE	SOWASHEE CREEK	600	EXCESSIVE RAINFALL - 1.5 INCHES	COLLECTED DEBRIS AND SPREAD LIME OVER AREA	NO INFORMATION PROVIDED	
3/19/2013	✓	✓	2PM		3/11/2013	7PM	3/11/2013	SOWASHEE STREET	MANHOLE	SOWASHEE CREEK	900	EXCESSIVE RAINFALL - 1.5 INCHES	COLLECTED DEBRIS AND SPREAD LIME OVER AREA	NO INFORMATION PROVIDED	
3/19/2013	✓	✓	2PM		3/11/2013	7PM	3/11/2013	65TH AVENUE	MANHOLE	DITCH TO SOWASHEE CREEK	3,000	EXCESSIVE RAINFALL - 1.5 INCHES	COLLECTED DEBRIS AND SPREAD LIME OVER AREA	NO INFORMATION PROVIDED	
3/19/2013	✓	✓	2PM		3/11/2013	8PM	3/12/2013	HWY 45 NORTH, EAST MERIDIAN WWTP	MANHOLE	SOWASHEE CREEK	9,000	EXCESSIVE RAINFALL - 1.5 INCHES	COLLECTED DEBRIS AND SPREAD LIME OVER AREA	NO INFORMATION PROVIDED	
3/21/2013	✓	✓	6PM		2/17/2013	10AM	2/18/2013	100 TO 65TH AVENUE	MANHOLE	SOWASHEE CREEK	10,000	EXCESSIVE RAINFALL - 8 INCHES THE WEEK PRIOR, PIPE RESTRICTION DUE TO JOINT FAILURE ALLOWING DIRT INTO SEWER LINE	REPAIRED AND WASHED LINE, COLLECTED DEBRIS AND SPREAD LIME OVER AREA	LINE REPAIRED AND WASHED	
3/21/2013	✓	✓	10PM		3/18/2013	11AM	3/19/2013	CHIP PICKERING DRIVE	PRESSURE LINE	SOWASHEE CREEK	177,000	BREAK IN LINE	SHUT OFF PUMP STATION	REPAIRED LINE	
3/21/2013	✓	✓	9AM		3/18/2013	6PM	3/19/2013	HWY 45 NORTH, EAST MERIDIAN WWTP ACCESS ROAD	MANHOLE	SOWASHEE CREEK	3,800	INFLOW & PIPE RESTRICTION	JETTED LINE TO ALLOW MORE FLOW THROUGH LINE, COLLECTED DEBRIS AND SPREAD LIME OVER AREA	NO INFORMATION PROVIDED	
3/21/2013	✓	✓	X		3/19/2013	1PM	3/19/2013	34TH & 10TH AVENUE	LINE	SOWASHEE CREEK	60,000	BANK COLLAPSED SHIFTING THE LINE, WHICH CAUSED THE RUBBERS IN PIPE JOINTS TO PUSH OUT	REPAIRED LINE	REPAIRED LINE	
3/29/2013	✓	✓	3PM		3/24/2013	4:30PM	3/24/2013	4524 HWY 39 NORTH	MANHOLE	SOWASHEE CREEK	180	GREASE BLOCKAGE	JETTED LINE, COLLECTED DEBRIS AND SPREAD LIME OVER AREA	NO INFORMATION PROVIDED	
3/29/2013	✓	✓	11:30AM		3/24/2013	2PM	3/27/2013	HWY 45 NORTH, EAST MERIDIAN WWTP ACCESS ROAD	MANHOLE	SOWASHEE CREEK	8,940	I&I, PIPE RESTRICTION	COLLECTED DEBRIS	NO INFORMATION PROVIDED	
5/1/2013	✓	✓	7AM		5/1/2013	X	X	EAST MERIDIAN WWTP, HWY 45 NORTH, EAST MERIDIAN WWTP ACCESS ROAD	MANHOLE	SOWASHEE CREEK	55,000	EXCESSIVE RAINFALL - 1.5 INCHES	REMOVE DEBRIS AND SPREAD LIME OVER AREA	NO INFORMATION PROVIDED	
5/13/2013	✓	✓	7:30AM		5/10/2013	12PM	5/11/2013	HWY 11/80 EAST AT CRACKER BARREL	MANHOLE	SOWASHEE CREEK	60,000	EXCESSIVE RAINFALL - 2 INCHES	REMOVE DEBRIS AND SPREAD LIME OVER AREA	NO INFORMATION PROVIDED	
5/13/2013		✓	7:30AM		5/10/2013	12PM	5/11/2013	EAST MERIDIAN WWTP, HWY 45 NORTH, EAST MERIDIAN WWTP ACCESS ROAD	MANHOLE	SOWASHEE CREEK	75,000	EXCESSIVE RAIN - 2 INCHES	LIME AREA	NO INFORMATION PROVIDED	
6/18/2013			9AM		3/25/2013	10AM	3/25/2013	27TH STREET AND 45TH AVENUE	PUMP STATION	SOWASHEE CREEK	4,500	PUMP FAILURE	STATION BROUGHT BACK ONLINE BY CITY PERSONNEL	REPLACED CONTROLLER PANEL AT STATION	
6/18/2013			9AM		6/17/2013	11AM	6/17/2013	CHIP PICKERING DRIVE	LINE	SOWASHEE CREEK	147,000	BLOWOUT IN PRESSURE LINE	REPAIRED LINE	REPAIR OF LINE	

Date SSO Event Report Received by MDEQ	SSO Reporting		City Notified of SSO Event			SSO Ceased		Location of SSO		Ultimate Destination of SSO	Volume of SSO, (gal) (approx.)	Cause of SSO	Corrective Actions to Stop SSO	Corrective Action to Prevent Future SSOs	Miscellaneous Information
	City of Meridian Excel Matrix	MDEQ Excel Matrix	Time		Date	Time	Date	Location	Source						
7/10/2013	✓		9:30AM		5/13/2013	1:30AM	5/17/2013	29TH AVENUE & SOWASHEE CREEK	24" SEWER LINE	SOWASHEE CREEK	120,000	BLOCKAGE IN LINE	REPAIR SEWER LINE, FLUSHED LINE AND CLEANED UP DEBRIS, LIME PUT DOWN OVER AREA	AT THIS TIME, CITY LOOKING TO REPLACE ABOUT 200' OF 24" SEWER LINE	SSO REPORT TO DEQ INCLUDED ATTACHMENT
8/15/2013	✓	✓	12AM		8/13/2013	10:30AM	8/14/2013	HWY 11/80 EAST AT CRACKER BARREL	MANHOLE	SOWASHEE CREEK	10,500	EXCESSIVE RAINFALL - 4 INCHES	COLLECTED DEBRIS AND SPREAD LIME OVER AREA	NO INFORMATION PROVIDED	
8/15/2013	✓	✓	12AM		8/13/2013	9AM	8/14/2013	HWY 45 NORTH, EAST MERIDIAN WWTP	MANHOLE	SOWASHEE CREEK	13,200	EXCESSIVE RAINFALL - 4 INCHES	COLLECTED DEBRIS AND SPREAD LIME OVER AREA	NO INFORMATION PROVIDED	
10/7/2013	✓		10PM		10/3/2013	9AM	10/4/2013	COTTON GIN ROAD	PUMP STATION	DITCH TO SOWASHEE CREEK	10,000	PUMP FAILURE	COLLECTED DEBRIS AND DISINFECTED AREA	REPAIRED PUMP	
11/13/2013	✓		11PM		11/4/2013	1PM	11/5/2013	CHIP PICKERING DRIVE	PRESSURE LINE	SOWASHEE CREEK	262,000	BREAK IN SEWER LINE	SPOT REPAIR OF LINE, COLLECTED DEBRIS AND DISINFECTED AREA	LINE REPAIRED	
11/13/2013	✓		X		11/9/2013	2:45PM	11/12/2013	CHIP PICKERING DRIVE	PRESSURE LINE	SOWASHEE CREEK	968,000	BREAK IN LINE	SPOT REPAIR OF LINE, COLLECTED DEBRIS AND DISINFECTED AREA	LINE REPAIRED	
1/13/2014	✓		9AM		1/9/2014	2:15PM	1/9/2014	CHIP PICKERING DRIVE	PRESSURE LINE	SOWASHEE CREEK	132,000	BLOWOUT IN PRESSURE LINE	SPOT REPAIR ON LINE	LINE REPAIRED	
1/21/2014	✓		8AM		1/17/2014	12NOON	1/17/2014	CHIP PICKERING DRIVE	PRESSURE LINE	SOWASHEE CREEK	127,000	BLOWOUT IN PRESSURE LINE	SPOT REPAIR ON LINE	LINE REPAIRED	
1/28/2014	✓		2AM		1/27/2014	2PM	1/27/2014	CHIP PICKERING DRIVE	PRESSURE LINE	SOWASHEE CREEK	145,000	BLOWOUT IN PRESSURE LINE	SPOT REPAIR ON LINE	LINE REPAIRED	
2/4/2014	✓		8AM		1/30/2014	2PM	1/30/2014	CHIP PICKERING DRIVE	PRESSURE LINE	SOWASHEE CREEK	130,000	BLOWOUT IN PRESSURE LINE	SPOT REPAIR ON LINE	LINE REPAIRED	
2/5/2014	✓		10PM		2/5/2014	12:30PM	2/5/2014	HWY 11/80 EAST AT CRACKER BARREL	MANHOLE	SOWASHEE CREEK	30-35 GALS	EXCESSIVE RAIN - 1.5 INCHES	COLLECTED DEBRIS AND SPREAD LIME OVER AREA	NO INFORMATION PROVIDED	
2/5/2014	✓		10PM		2/4/2014	12:30PM	2/5/2014	HWY 45 NORTH, EAST MERIDIAN WWTP	MANHOLE	SOWASHEE CREEK	40-50 GPM	EXCESSIVE RAIN - 1.5 INCHES	COLLECTED DEBRIS AND SPREAD LIME OVER AREA	NO INFORMATION PROVIDED	
2/13/2014	✓		7AM		2/10/2014	2PM	2/10/2014	CHIP PICKERING DRIVE	PRESSURE LINE	SOWASHEE CREEK	140,000	BREAK IN LINE	SPOT REPAIR	LINE REPAIRED	
2/18/2014	✓		2:30PM		2/15/2014	8PM	2/15/2014	CHIP PICKERING DRIVE	PRESSURE LINE	SOWASHEE CREEK	125,000	BREAK IN LINE	SPOT REPAIR	LINE REPAIRED	
3/4/2014	✓		5AM		2/21/2014	3PM	2/21/2014	CHIP PICKERING DRIVE	PRESSURE LINE	SOWASHEE CREEK	147,000	BREAK IN LINE	SPOT REPAIR	LINE REPAIRED	
3/14/2014	✓		7AM		3/10/2014	1:30PM	3/10/2014	CHIP PICKERING DRIVE	PRESSURE LINE	SOWASHEE CREEK	138,000	BREAK IN LINE	SPOT REPAIR	LINE REPAIRED	
3/28/2014	✓		12AM		2/28/2014	ONGOING	ONGOING	HWY 11/80 EAST AT CRACKER BARREL	MANHOLE	SOWASHEE CREEK	45 GPM	EXCESSIVE RAINFALL - 1.5 INCHES	COLLECTED DEBRIS AND DISINFECTED AREA	NO INFORMATION PROVIDED	
3/28/2014	✓		12AM		3/28/2014	ONGOING	ONGOING	SOWASHEE STREET	MANHOLE	SOWASHEE CREEK	30-35 GPM	EXCESSIVE RAINFALL - 1.5 INCHES	COLLECTED DEBRIS AND DISINFECTED AREA	NO INFORMATION PROVIDED	
3/28/2014	✓		12AM		3/28/2014	ONGOING	ONGOING	HWY 45 NORTH, EAST MERIDIAN WWTP	MANHOLE	SOWASHEE CREEK	60,000	EXCESSIVE RAINFALL - 1.5 INCHES	COLLECTED DEBRIS AND DISINFECTED AREA	NO INFORMATION PROVIDED	
4/8/2014	✓		5PM		4/13/2014	3PM	4/15/2014	HWY 11/80 EAST, BEHIND STRIBLING EQUIPMENT	MANHOLE	SOWASHEE CREEK	408,000	EXCESSIVE RAINFALL - 5 INCHES	COLLECTED DEBRIS AND DISINFECTED AREA	NO INFORMATION PROVIDED	
4/8/2014	✓		8PM		4/4/2014	10PM	4/8/2014	HWY 11/80 EAST, BEHIND STRIBLING EQUIPMENT	MANHOLE	SOWASHEE CREEK	200 GPM	EXCESSIVE RAINFALL - 6 INCHES	COLLECTED DEBRIS AND DISINFECTED AREA	NO INFORMATION PROVIDED	
4/22/2014	✓		6PM		4/13/2014	2PM	4/16/2014	HWY 45 NORTH, EAST MERIDIAN WWTP	MANHOLE	SOWASHEE CREEK	365,000	EXCESSIVE RAINFALL - 4 INCHES	COLLECTED DEBRIS AND DISINFECTED AREA	NO INFORMATION PROVIDED	
4/22/2014	✓		8PM		4/4/2014	7PM	4/9/2014	HWY 45 NORTH, EAST WWTP ENTRANCE	MANHOLE	SOWASHEE CREEK	535,000	EXCESSIVE RAINFALL - 4 INCHES	COLLECTED DEBRIS AND DISINFECTED AREA	NO INFORMATION PROVIDED	
					4/8/2014			SOWASHEE STREET	MANHOLE	SOWASHEE CREEK					
					4/8/2014			SOWASHEE STREET	MANHOLE	SOWASHEE CREEK					
					4/8/2014			SOWASHEE STREET	MANHOLE	SOWASHEE CREEK					
4/22/2014	✓		3PM		4/13/2014	2PM	4/15/2014	HWY 11/80 EAST AT CRACKER BARREL	MANHOLE	SOWASHEE CREEK	211,500	EXCESSIVE RAINFALL - 4 INCHES	COLLECTED DEBRIS AND DISINFECTED AREA	NO INFORMATION PROVIDED	
4/22/2014	✓		8PM		4/4/2014	6PM	4/7/2014	HWY 11/80 EAST AT CRACKER BARREL	MANHOLE	SOWASHEE CREEK	315,000	EXCESSIVE RAINFALL - 4 INCHES	COLLECTED DEBRIS AND DISINFECTED AREA	NO INFORMATION PROVIDED	



City of Meridian, Mississippi
List of SSOs from September 2008 to May 6, 2014

Date SSO Event Report Received by MDEQ	SSO Reporting		City Notified of SSO Event			SSO Ceased		Location of SSO		Ultimate Destination of SSO	Volume of SSO, (gal) (approx.)	Cause of SSO	Corrective Actions to Stop SSO	Corrective Action to Prevent Future SSOs	Miscellaneous Information
	City of Meridian Excel Matrix	MDEQ Excel Matrix	Time		Date	Time	Date	Location	Source						
BYPASSES															
1/8/2010			NOT AVAILABLE		12/17/2009	NOT AVAILABLE	1/8/2010	SOUTH WWTP	EQ BASINS	SOWASHEE CREEK	19,430,000	DUE TO CONTINUOUS RAINY DAYS AND PORTION OF MAIN PLANT BEING OFFLINE, PLANT WAS FORCED TO DIVERTED PORTION OF NORMAL	ONCE PORTION OF MAIN PLANT WAS BROUGHT BACK ONLINE, PLANT CEASED BYPASSING TO EQ BASINS	PLAN TO REPLACE FLEXIBLE CURTAIN IN BASIN AND DREDGING OF SOLIDS FROM WITHIN BASIN TO INCREASE CAPACITY	RECORDED FROM NPDES EXCEEDANCE LETTER TO MDEQ
2/22/2010			NOT AVAILABLE		FEB. 2010	NOT AVAILABLE	2/22/2010	SOUTH WWTP	EQ BASINS	SOWASHEE CREEK	21,000,000	PART OF MAIN PLANT OFFLINE DUE TO PUMP REPAIRS, RESULTING IN DIVERSION TO EQ BASINS	ONCE PORTION OF MAIN PLANT BROUGHT BACK ONLINE FOLLOWING INSTALLATION OF NEW MOTOR ON PRIMARY SLUDGE PUMPS	PLAN TO REPLACE FLEXIBLE CURTAIN IN BASIN AND DREDGING OF SOLIDS FROM WITHIN BASIN TO INCREASE CAPACITY	RECORDED FROM NPDES EXCEEDANCE LETTER TO MDEQ
MAR. 2010			NOT AVAILABLE		MAR. 2010	NOT AVAILABLE	MAR. 2010	SOUTH WWTP	EQ BASINS	SOWASHEE CREEK	51,050,000	DUE TO CONTINUOUS RAINY DAYS AND PORTION OF MAIN PLANT BEING OFFLINE, PLANT WAS FORCED TO DIVERTED PORTION OF FLOW TO EQ BASINS	ONCE PORTION OF MAIN PLANT WAS BROUGHT BACK ONLINE, PLANT CEASED BYPASSING TO EQ BASINS	PLAN TO REPLACE FLEXIBLE CURTAIN IN BASIN AND DREDGING OF SOLIDS FROM WITHIN BASIN TO INCREASE CAPACITY	
3/24/2011			NOT AVAILABLE		3/11/2011	NOT AVAILABLE	3/11/2011	SOUTH WWTP	EQ BASINS	SOWASHEE CREEK	9,800,000	PLANT WAS FORCED TO DIVERTED PORTION OF FLOW TO EQ BASINS	ONCE INFLUENT FLOW DECREASED, PLANT CEASED BYPASSING TO EQ BASINS	PLAN TO REPLACE FLEXIBLE CURTAIN IN BASIN AND DREDGING OF SOLIDS FROM WITHIN BASIN TO INCREASE CAPACITY	
SSOs															
1/14/2010	✓		10:30AM		12/18/2009	2PM	12/21/2009	HAMILTON AVENUE	MANHOLE	SOWASHEE CREEK	170,000	EXCESSIVE RAINFALL - 3.5 INCHES TO 4 INCHES	NO INFORMATION PROVIDED	NO INFORMATION PROVIDED	
1/19/2010	✓		12PM		1/13/2010	10AM	1/14/2010	FRED CLAYTON ROAD	PRESSURE LINE	LOST HORSE CREEK	290,000	BROKEN LINE	REPAIRED LINE	REPAIRED LINE	
1/24/2010	✓		NOT AVAILABLE		2/21/2010	NOT AVAILABLE	2/24/2010	4001 NEWELL ROAD	MANHOLE	SOWASHEE CREEK	170,000	GREASE AND ROOTS IN MANHOLE, 3+ INCHES OF RAIN AND 4 INCHES OF SNOW	FLUSHED LINE	CLEANED ROOTS FROM MANHOLE AND REPAIRED PIPE	
3/15/2010	✓		MIDNIGHT		3/10/2010	NOT AVAILABLE	NOT AVAILABLE	SOWASHEE STREET	MANHOLE	SOWASHEE CREEK	75,000	EXCESSIVE RAINFALL - 2+ INCHES	CITY CREWS WORKING ON PROBLEM AT CHIP MILL	PLANS ARE BEING PUT IN PLACE TO INCREASE CAPACITY IN LINE	
3/15/2010	✓		2:33PM		3/12/2010	7PM	3/15/2010	HWY 45 & HWY 39	RAISED MANHOLE	SOWASHEE CREEK	200,000	HIGH RAINFALL & MANHOLE INFILTRATION	REPAIR MANHOLE	CITY CREWS WORKING ON CHIPMILL PROBLEM	
3/23/2010	✓		MIDNIGHT		3/10/2010	9:45AM	3/16/2010	SOWASHEE STREET	MANHOLE	SOWASHEE CREEK	95,000	EXCESSIVE RAINFALL - 2+ INCHES	CITY CREWS WORKING ON PROBLEM AT CHIP MILL	PLANS ARE BEING PUT IN PLACE TO INCREASE CAPACITY IN LINE	
3/24/2010			11AM		3/24/2010	2PM	3/24/2010	SOWASHEE STREET (BEHIND MISSISSIPPI MUSIC)	MANHOLE	TRIBUTARY OF SOWASHEE CREEK	NO INFORMATION AVAILABLE	NO INFORMATION AVAILABLE	CITY CREWS COLLECTED DEBRIS, EXCAVATED AFFECTED SOIL, AND LIMED IMPACTED AREA	NO INFORMATION PROVIDED	INFORMATION RECORDED FROM MARCH 25, 2010 MEMORANDUM FROM MDEQ
11/24/2010	✓	✓	7AM		11/24/2010	10:30AM	11/24/2010	26TH STREET/2606 EDGEWOOD DRIVE	MANHOLE	SOWASHEE CREEK	80,000	ROOTS IN MANHOLE	FLUSH TRUCK 'SHOT LINE' & OPEN IT	CREW CUT ROOTS OUT OF MANHOLE	FULL REPORT INCLUDES PICTURES
1/13/2011	✓		3AM		1/7/2011	8AM	1/7/2011	3900 OLD HWY 45 N.	MANHOLE	UNSPECIFIED	40,000	POWER FAILURE AT PLANT	RESET MAIN POWER BREAKER	NEW GROUND TO BLOWER MOTOR	

Date SSO Event Report Received by MDEQ	SSO Reporting		City Notified of SSO Event			SSO Ceased		Location of SSO		Ultimate Destination of SSO	Volume of SSO, (gal) (approx.)	Cause of SSO	Corrective Actions to Stop SSO	Corrective Action to Prevent Future SSOs	Miscellaneous Information
	City of Meridian Excel Matrix	MDEQ Excel Matrix	Time		Date	Time	Date	Location	Source						
2/10/2011	✓	✓	NOT AVAILABLE		1/31/2011	NOT AVAILABLE	2/10/2011	HILLCREST DRIVE/BROADHEAD PROPERTY	MANHOLE	UNSPECIFIED	25,000	TREE ROOTS	SPREAD LIME OVER AREA	PLANS TO REPLACE MANHOLE & REMOVE TREE THIS WEEK - WEATHER PERMITTING	FULL REPORT INCLUDES PICTURES
2/15/2011	✓		1PM		2/11/2011	9AM	2/14/2011	HYUNDAI HWY 39	MANHOLE	SOWASHEE CREEK	4,000	GREASE IN MANHOLE	FLUSHED LINES	RED HOT COMPOUND USED TO CLEAN LINE	
2/17/2011	✓		10:30AM		2/17/2011	11:30AM	2/17/2011	SHUMATE ROAD	MANHOLE	UNSPECIFIED	300	GREASE BLOCKAGE	FLUSHED LINES, RED HOT COMPOUND USED TO CLEAN LINE	LOCATION ADDED TO A BI-WEEKLY FLUSHING SCHEDULE	
3/10/2011	✓	✓	10PM ON SSO, 2AM CITY		3/8/2011	2AM	3/9/2011	SOWASHEE STREET	MANHOLE	SOWASHEE CREEK	8,400	EXCESSIVE RAINFALL - 6 INCHES	COLLECTED DEBRIS AND DISINFECTED AREA	NO INFORMATION PROVIDED	
3/10/2011	✓	✓	8PM		3/8/2011	6PM	3/10/2011	HWY 11/80 & RUSSELL DRIVE ON 8 INCH LINE THAT CONNECTS TO A 24 INCH LINE, BEHIND STRIBLING EQUIPMENT	MANHOLE	SOWASHEE CREEK	229,950	EXCESSIVE RAINFALL - 6 INCHES	COLLECTED DEBRIS AND DISINFECTED AREA	NO INFORMATION PROVIDED	
3/10/2011	✓	✓	8PM		3/8/2011	6PM	3/10/2011	HWY 11/80 AT CRACKER BARREL	MANHOLE	SOWASHEE CREEK	65,000	EXCESSIVE RAINFALL - 6 INCHES	COLLECTED DEBRIS AND DISINFECTED AREA	NO INFORMATION PROVIDED	
4/6/2011	✓		4AM		4/4/2011	7:30AM	4/4/2011	3900 OLD HWY 45 S.	INFLUENT LIFT STATION	UNSPECIFIED	25,000	POWER FAILURE	RESET MAIN POWER BREAKER	ADJUSTED ELECTRICAL PANEL AND GROUND FAULT SENSORS	
4/29/2011	✓	✓	5PM		4/28/2011	8PM	4/28/2011	HWY 11/80 AT STRIBLING EQUIPMENT	MANHOLE	SOWASHEE CREEK	225	I&I, 3 INCHES OF RAIN, AS WELL AS PREVIOUS RAIN IN PAST 2 WEEKS	NO INFORMATION PROVIDED	NO INFORMATION PROVIDED	
7/14/2011	✓	✓	2PM		6/16/2011	2PM	7/6/2011	15TH PLACE	MANHOLE	SOWASHEE CREEK	250,000	COMBINATION OF ROOTS & GREASE, A COLLAPSED LINE	JETTED & BROKE THE BLOCKAGE, REPLACED DAMAGED LINE	REPLACED LINE	NOTIFIED OF BAD SEWER ODOR ON JULY 5, 2011
7/26/2011	✓		2PM		7/25/2011	5PM	7/25/2011	HWY 11/80 CRACKER BARREL	MANHOLE	SOWASHEE CREEK	1,800	HIGH RAINFALL OF 1.5 INCHES	CLEANED DEBRIS AND SANITIZED	NO INFORMATION PROVIDED	
7/26/2011	✓		2PM		7/25/2011	5PM	7/25/2011	SOWASHEE STREET	MANHOLE	SOWASHEE CREEK	2,700	HIGH RAINFALL OF 1.5 INCHES	NO INFORMATION PROVIDED	NO INFORMATION PROVIDED	
7/26/2011	✓	✓	3:30PM		7/25/2011	4:30PM	7/25/2011	56TH AVENUE @ ROYAL ROAD	MANHOLE	GALLAGHER CREEK	1,000	EXCESSIVE RAINFALL - 1 INCH	CLEANED DEBRIS (SMALL AMOUNTS OF PAPER & GREASE) & SPRAYED DISINFECTANT OVER ENTIRE AREA	NO INFORMATION PROVIDED	
11/18/2011	✓	✓	7AM		11/16/2011	1PM	11/16/2011	OLD 8TH STREET & 70TH PLACE	PUMP STATION	SOWASHEE CREEK	12,000	PUMP FAILURE	CLEANED DEBRIS & USED DISINFECTANT TO KILL BACTERIA IN THE AREA	PUMP REPAIRED	FULL REPORT INCLUDES PICTURES
11/21/2011	✓	✓	2:30PM		11/18/2011	10:30PM	11/18/2011	29TH AVENUE, SOUTH BANK, APPROXIMATELY 200 YARDS WEST OF 29TH AVENUE BRIDGE/RR	MANHOLE	SOWASHEE CREEK	48,000	CAVE-IN, STORMWATER DRAIN	DIRT REMOVED TO ALLOW SEWAGE TO FLOW, TRENCH BOX PUT INTO PLACE TO PROTECT THE LINE	LINE WILL BE REPLACED WITH A LARGER LINE	FULL REPORT INCLUDES PICTURES
12/2/2011		✓	10AM		11/30/2011	1AM	12/1/2011	29TH AVENUE @ RR	MAIN LINE	SOWASHEE CREEK	700,000	PUMP FAILURE & SEPARATION IN LINE	SWITCHED OUT PORTABLE PUMP, REPAIRED LINE, LIME WAS SPREAD OVER ENTIRE AREA	REPAIRED LINE AND SWITCHED OUT PUMP	FULL REPORT INCLUDES PICTURES
1/3/2012	✓	✓	10AM		12/29/2011	2:30PM	12/29/2011	11/80 EAST AT CRACKER BARREL	MANHOLE	SOWASHEE CREEK	5,400	GREASE BLOCKAGE	GREASE REMOVED BY FLUSH TRUCK, DEBRIS COLLECTED & REMOVED, LIME WAS SPREAD OVER ENTIRE AREA	NO INFORMATION PROVIDED	
1/27/2012	✓		10AM		1/26/2012	2PM	1/26/2012	5310 OVERBROOK LANE	MANHOLE	UNSPECIFIED	10 gpm	GREASE BLOCKAGE & INFLOW	JETTED LINE TO BREAK BLOCKAGE & RESUME NORMAL FLOW, DEBRIS COLLECTED & REMOVED, LIME WAS SPREAD OVER ENTIRE AREA	JETTED LINE TO BREAK BLOCKAGE & RESUME NORMAL FLOW	
1/27/2012	✓		10AM		1/26/2012	5PM	1/26/2012	SOWASHEE STREET	MANHOLE	SOWASHEE CREEK	20 gpm	INFLOW - 3 INCHES OF RAIN	DEBRIS COLLECTED & REMOVED, LIME WAS SPREAD OVER ENTIRE AREA	NO INFORMATION PROVIDED	

Date SSO Event Report Received by MDEQ	SSO Reporting		City Notified of SSO Event			SSO Ceased		Location of SSO		Ultimate Destination of SSO	Volume of SSO, (gal) (approx.)	Cause of SSO	Corrective Actions to Stop SSO	Corrective Action to Prevent Future SSOs	Miscellaneous Information
	City of Meridian Excel Matrix	MDEQ Excel Matrix	Time		Date	Time	Date	Location	Source						
1/27/2012	✓		10AM		1/26/2012	6PM	1/26/2012	HWY 11/80 EAST AT CRACKER BARREL	MANHOLE	SOWASHEE CREEK	20 gpm	INFLOW - 3 INCHES OF RAIN	DEBRIS COLLECTED & REMOVED, LIME WAS SPREAD OVER ENTIRE AREA	NO INFORMATION PROVIDED	
1/27/2012	✓		9AM		1/26/2012	2PM	1/26/2012	26TH STREET & 40TH AVENUE	MAIN LINE	NO INFORMATION PROVIDED	4,500	INFLOW - 3 INCHES OF RAIN	DEBRIS COLLECTED & REMOVED, LIME WAS SPREAD OVER ENTIRE AREA	NO INFORMATION PROVIDED	
2/3/2012	✓		8AM		1/27/2012	10AM	1/30/2012	3109 GRANDVIEW AVENUE	LINE	SOWASHEE CREEK	15gpm	BROKEN PIPE	REPLACED BROKEN PIPE, LIME WAS SPREAD OVER ENTIRE AREA	REPLACED BROKEN PIPE	
2/3/2012	✓		1PM		1/30/2012	2PM	1/31/2012	5525 CHEROKEE ROAD	MANHOLE	SOWASHEE CREEK	10 gpm	BROKEN PIPE	REPLACED BROKEN PIPE, LIME WAS SPREAD OVER ENTIRE AREA	REPLACED BROKEN PIPE	
2/3/2012	✓		11AM		2/2/2012	6PM	2/2/2012	600 FRONTAGE ROAD	LINE	SOWASHEE CREEK	60 gpm	BROKEN PIPE	REPLACED BROKEN PIPE, LIME WAS SPREAD OVER ENTIRE AREA	REPLACED BROKEN PIPE	
2/3/2012	✓		11AM		2/2/2012	5PM	2/2/2012	2900 SAINT PAUL STREET	LINE	SOWASHEE CREEK	60 gpm	BROKEN PIPE	REPLACED BROKEN PIPE, LIME WAS SPREAD OVER ENTIRE AREA	REPLACED BROKEN PIPE	
3/2/2012	✓		10AM		2/28/2012	6PM	2/28/2012	SOWASHEE STREET	MANHOLE	SOWASHEE CREEK	9,600	INFLOW - 1 INCH OF RAIN	DEBRIS COLLECTED & REMOVED, LIME WAS SPREAD OVER ENTIRE AREA	NO INFORMATION PROVIDED	
3/2/2012	✓		10AM		2/28/2012	8:30AM	2/29/2012	HWY 11/80 EAST AT CRACKER BARREL	MANHOLE	SOWASHEE CREEK	168,750	GREASE BLOCKAGE	GREASE REMOVED BY FLUSH TRUCK, DEBRIS COLLECTED & REMOVED, LIME WAS SPREAD OVER ENTIRE AREA	NO INFORMATION PROVIDED	
3/26/2012			4PM		3/21/2012	7AM	3/24/2012	SOWASHEE STREET	MANHOLE	SOWASHEE CREEK	96,000	EXCESSIVE RAINFALL - 3.5 INCHES	WORK ON PROBLEM AT CHIP MILL	PLANS TO REPLACE OLD SEWER LINE, INCREASE NEW LINE	
3/26/2012			4PM		3/21/2012	7AM	3/24/2012	HWY 11/80 EAST AT CRACKER BARREL	MANHOLE	SOWASHEE CREEK	65,000	EXCESSIVE RAINFALL - 3.5 INCHES	CLEANED UP	PLANS TO INCREASE LINE AT CHIP MILL	
3/26/2012			4PM		3/21/2012	7AM	3/24/2012	HWY 11/80 EAST & RUSSELL STREET, BEHIND STRIBLING EQUIPMENT	MANHOLE	SOWASHEE CREEK	100,000	EXCESSIVE RAINFALL - 3.5 INCHES	NO INFORMATION PROVIDED	PLANS TO INCREASE LINE AT CHIP MILL	
4/2/2012	✓	✓	10:30AM		3/29/2012	11:15AM	3/29/2012	HWY 11/CELOTEX	MANHOLE	SOWASHEE CREEK	600,000	PUMP STATION FAILURE	PUMP WAS RESET, LIME WAS SPREAD OVER THE ENTIRE AREA	PUMP WAS RESET	
6/25/2012		✓	7AM		6/25/2012	8:30AM	6/25/2012	HWY 39, NUMBER 1 LIFT STATION	PUMP STATION	SOWASHEE CREEK	50,000	POWER FAILURE	RESTORED POWER, COLLECTED ALL DEBRIS, SPREAD LIME OVER THE ENTIRE AREA	POWER RESTORED TO PUMP STATION	
8/1/2012	✓	✓	8PM		7/26/2012	8:30AM	7/27/2012	29TH AVENUE	MANHOLE	NONE	35,000	BROKEN LINE	REPAIRED LINE, DEBRIS COLLECTED & REMOVED, LIME WAS SPREAD OVER ENTIRE AREA	REPAIR OF LINE	
8/20/2012		✓	3:30PM		8/18/2012	6PM	NOT AVAILABLE	TOMMY WEBB DRIVE	MANHOLE	SOWASHEE CREEK	200,000	I&I, 2 INCHES OF RAINFALL	NO INFORMATION PROVIDED	NO INFORMATION PROVIDED	
12/17/2012	✓		10AM		12/17/2012	8PM	12/17/2012	CHIP PICKERING DRIVE AND STENNIS DRIVE	PIPE	SOWASHEE CREEK	320,000	BROKEN PIPE	STOPPED PUMP TO CEASE FLOW, REPAIRED PIPE AND SPREAD LIME OVER ENTIRE AREA	REPAIRED PIPE LINE	
1/4/2013	✓	✓	3:30PM		12/28/2012	NOT AVAILABLE	12/29/2012	HWY 45 SOUTH, BEHIND MS POWER	MANHOLE	SOWASHEE CREEK	350,000	BLOCKAGE	FLUSHED LINE & CLEANED DEBRIS, LIME WAS SPREAD OVER ENTIRE AREA	NO INFORMATION PROVIDED	
1/4/2013	✓	✓	8PM		12/29/2012	11PM	12/29/2012	HWY 11/80 EAST AT CRACKER BARREL	MANHOLE	SOWASHEE CREEK	18,000	EXCESSIVE RAINFALL	DEBRIS COLLECTED & REMOVED, LIME WAS SPREAD OVER ENTIRE AREA	NO INFORMATION PROVIDED	
1/4/2013	✓	✓	8PM		12/30/2012	11PM	12/30/2012	SOWASHEE STREET	MANHOLE	DITCH TO SOWASHEE CREEK	1,800	EXCESSIVE RAINFALL - 1.5 INCHES	DEBRIS COLLECTED & REMOVED, LIME WAS SPREAD OVER ENTIRE AREA	NO INFORMATION PROVIDED	
1/14/2013	✓	✓	7PM		1/12/2013	6AM	1/13/2013	HWY 45 NORTH , EAST MERIDIAN WWTP	MANHOLE	SOWASHEE CREEK	13,200	EXCESSIVE RAINFALL - ABOUT 2 INCHES	COLLECTED DEBRIS AND SPREAD LIME OVER AREA	NO INFORMATION PROVIDED	
1/14/2013	✓	✓	6PM		1/12/2013	NOT AVAILABLE	1/14/2013	HWY 11/80 EAST AT CRACKER BARREL	MANHOLE	SOWASHEE CREEK	72,000	EXCESSIVE RAINFALL - ABOUT 2 INCHES	COLLECTED DEBRIS	NO INFORMATION PROVIDED	ONGOING

Date SSO Event Report Received by MDEQ	SSO Reporting		City Notified of SSO Event			SSO Ceased		Location of SSO		Ultimate Destination of SSO	Volume of SSO, (gal) (approx.)	Cause of SSO	Corrective Actions to Stop SSO	Corrective Action to Prevent Future SSOs	Miscellaneous Information
	City of Meridian Excel Matrix	MDEQ Excel Matrix	Time		Date	Time	Date	Location	Source						
1/14/2013	✓	✓	6PM		1/12/2013	6AM	1/13/2013	SOWASHEE STREET	MANHOLE	SOWASHEE CREEK	10,800	EXCESSIVE RAINFALL - 2 INCHES	COLLECTED DEBRIS AND SPREAD LIME OVER AREA	NO INFORMATION PROVIDED	
1/28/2013	✓	✓	10AM		1/16/2013	10AM	1/19/2013	SOWASHEE STREET	MANHOLE	SOWASHEE CREEK	51,000	EXCESSIVE RAINFALL - ABOUT 8 INCHES FOR THE MONTH, A COLLAPSED LINE	COLLECTED DEBRIS AND SPREAD LIME OVER AREA	REPAIRED LINE	
1/28/2013	✓	✓	10AM		1/16/2013	8AM	1/17/2013	HWY 11/80, BEHIND STRIBLING EQUIPMENT	MANHOLE	SOWASHEE CREEK	66,000	EXCESSIVE RAINFALL - ABOUT 8 INCHES FOR THE MONTH, A COLLAPSED LINE	SPREAD LIME OVER AREA	REPAIRED LINE	
1/28/2013	✓	✓	10AM		1/16/2013	8AM	1/21/2013	HWY 45 NORTH, EAST MERIDIAN WWTP	MANHOLE	SOWASHEE CREEK	142,000	EXCESSIVE RAINFALL - ABOUT 8 INCHES FOR THE MONTH, A COLLAPSED LINE	COLLECTED DEBRIS AND SPREAD LIME OVER AREA	REPAIRED LINE	
1/28/2013	✓	✓	10AM		1/16/2013	12NOON	1/23/2013	HWY 11/80 EAST AT CRACKER BARREL	MANHOLE	SOWASHEE CREEK	151,200	EXCESSIVE RAINFALL - ABOUT 8 INCHES FOR THE MONTH, A COLLAPSED LINE	COLLECTED DEBRIS AND SPREAD LIME OVER AREA	REPAIRED LINE	
1/28/2013	✓	✓	1PM		1/23/2013	7PM	1/23/2013	29TH AVENUE, MULTI-COUNTY	MAHNOLE	SOWASHEE CREEK	1,500	BLOCKAGE IN SEWER LINE	COLLECTED DEBRIS, SPREAD LIME OVER AREA	NO INFORMATION PROVIDED	
2/1/2013	✓	✓	11AM		1/30/2013	8PM	1/30/2013	HWY 45 NORTH, ENTRANCE TO EAST MERIDIAN WWTP	MANHOLE	SOWASHEE CREEK	8,100	EXCESSIVE RAINFALL - ABOUT 2 INCHES	COLLECTED DEBRIS, SPREAD LIME OVER AREA	NO INFORMATION PROVIDED	
2/1/2013	✓	✓	11AM		1/30/2013	8PM	1/30/2013	SOWASHEE STREET	MANHOLE	SOWASHEE CREEK	2,700	EXCESSIVE RAINFALL - ABOUT 2 INCHES	COLLECTED DEBRIS, SPREAD LIME OVER AREA	NO INFORMATION PROVIDED	
2/1/2013	✓	✓	11AM		1/30/2013	8PM	1/30/2013	HWY 11/80, BEHIND STRIBLING EQUIPMENT	MANHOLE	SOWASHEE CREEK	10,800	EXCESSIVE RAINFALL - ABOUT 2 INCHES	NO INFORMATION PROVIDED	NO INFORMATION PROVIDED	
2/1/2013	✓	✓	11AM		1/30/2013	8PM	1/30/2013	HWY 11/80 AT CRACKER BARREL	MANHOLE	SOWASHEE CREEK	5,400	EXCESSIVE RAINFALL - ABOUT 2 INCHES	NO INFORMATION PROVIDED	NO INFORMATION PROVIDED	
2/11/2013	✓	✓	5PM		2/6/2013	2PM	2/7/2013	CHIP PICKERING DRIVE	MAIN LINE	SOWASHEE CREEK	300,000	BREAK IN LINE	SPREAD LIME OVER AREA	REPAIRED LINE	
2/14/2013	✓		1PM		2/13/2013	10PM	2/13/2013	65TH AVENUE (MAPLE GAS TERMINAL)	MANHOLE	SOWASHEE CREEK	10,800	EXCESSIVE RAINFALL - 6.74 INCHES BETWEEN 2/10/13 TO 2/12/13	NO INFORMATION PROVIDED	NO INFORMATION PROVIDED	
2/14/2013	✓		9AM		2/12/2013	11PM	2/12/2013	40TH AVENUE & 26 STREET	MANHOLE	SOWASHEE CREEK	2,520	EXCESSIVE RAINFALL - 2.9 INCHES 2/11/2013 TO 2/12/3013	COLLECTED DEBRIS AND SPREAD LIME OVER AREA	NO INFORMATION PROVIDED	
2/14/2013	✓		9AM		2/12/2013	11PM	2/12/2013	26 & 41ST STREET	MANHOLE	SOWASHEE CREEK	4,200	EXCESSIVE RAINFALL - 2.9 INCHES 2/11/2013 TO 2/12/3013	COLLECTED DEBRIS AND SPREAD LIME OVER AREA	NO INFORMATION PROVIDED	
2/14/2013	✓		8PM		2/10/2013	NOT AVAILABLE	2/13/2013	HWY 45 NORTH (EAST MERIDIAN WWTP ENTRANCE)	MANHOLE	SOWASHEE CREEK	42,000	EXCESSIVE RAINFALL - 6.74 INCHES BETWEEN 2/10/13 TO 2/12/13	COLLECTED DEBRIS AND SPREAD LIME OVER AREA	NO INFORMATION PROVIDED	
2/14/2013	✓		8PM		2/10/2013	6PM	2/13/2013	HWY 11 & 80 AT CRACKER BARREL	MANHOLE	SOWASHEE CREEK	70,800	EXCESSIVE RAINFALL -6.74 INCHES	COLLECTED DEBRIS AND SPREAD LIME OVER AREA	NO INFORMATION PROVIDED	
2/14/2013	✓		8PM		2/10/2013	6PM	2/13/2013	HWY 11 & 80, BEHIND STRIBLING EQUIPMENT	MANHOLE	SOWASHEE CREEK	84,000	EXCESSIVE RAINFALL - 6.74 INCHES BETWEEN 2/10/13 TO 2/12/13	COLLECTED DEBRIS AND SPREAD LIME OVER AREA	NO INFORMATION PROVIDED	
2/14/2013	✓		6PM		2/11/2013	10PM	2/12/2013	SOWASHEE STREET	MANHOLE	SOWASHEE CREEK	4,800	EXCESSIVE RAINFALL - 2.9 INCHES	COLLECTED DEBRIS AND SPREAD LIME OVER AREA	NO INFORMATION PROVIDED	
2/14/2013	✓		8PM		2/10/2013	10AM	2/11/2013	SOWASHEE STREET	MANHOLE	SOWASHEE CREEK	4,200	EXCESSIVE RAINFALL - 3.48 INCHES	COLLECTED DEBRIS AND SPREAD LIME OVER AREA	IDENTIFY I&I SPOTS IN LINE AND MAKE SPOT REPAIRS, TWO BREAKS AND ONE MANHOLE HAVE BEEN IDENTIFIED, REPAIRS BEGAN 2/14/2013 ON THESE	
2/14/2013	✓		8PM		2/10/2013	10AM	2/11/2013	HWY 145 & SOWASHEE STREET	MANHOLE	SOWASHEE CREEK	1,680	EXCESSIVE RAINFALL - 3.48 INCHES	COLLECTED DEBRIS AND SPREAD LIME OVER AREA	NO INFORMATION PROVIDED	
2/14/2013	✓		1PM		2/13/2013	2PM	2/13/2013	OLD 8TH STREET	MANHOLE	SOWASHEE CREEK	300	PUMP FAILURE DUE TO RAGS PREVENTING IMPALERS FROM TURNING	COLLECTED DEBRIS AND SPREAD LIME OVER AREA, PULLED PUMP TO BE REPAIRED	REPAIR OF PUMP	
3/19/2013	✓	✓	2PM		3/11/2013	7PM	3/11/2013	HWY 11/80, BEHIND STRIBLING EQUIPMENT	MANHOLE	SOWASHEE CREEK	6,000	EXCESSIVE RAINFALL - 1.5 INCHES	SPREAD LIME OVER AREA	NO INFORMATION PROVIDED	

Date SSO Event Report Received by MDEQ	SSO Reporting		City Notified of SSO Event			SSO Ceased		Location of SSO		Ultimate Destination of SSO	Volume of SSO, (gal) (approx.)	Cause of SSO	Corrective Actions to Stop SSO	Corrective Action to Prevent Future SSOs	Miscellaneous Information
	City of Meridian Excel Matrix	MDEQ Excel Matrix	Time		Date	Time	Date	Location	Source						
3/19/2013	✓	✓	2PM		3/11/2013	7PM	3/11/2013	HWY 11/80 AT CRACKER BARREL	MANHOLE	SOWASHEE CREEK	3,000	EXCESSIVE RAINFALL - 1.5 INCHES	COLLECTED DEBRIS AND SPREAD LIME OVER AREA	NO INFORMATION PROVIDED	
3/19/2013	✓	✓	2PM		3/11/2013	7PM	3/11/2013	PARKWAY BOULEVARD	MANHOLE	SOWASHEE CREEK	600	EXCESSIVE RAINFALL - 1.5 INCHES	COLLECTED DEBRIS AND SPREAD LIME OVER AREA	NO INFORMATION PROVIDED	
3/19/2013	✓	✓	2PM		3/11/2013	7PM	3/11/2013	SOWASHEE STREET	MANHOLE	SOWASHEE CREEK	900	EXCESSIVE RAINFALL - 1.5 INCHES	COLLECTED DEBRIS AND SPREAD LIME OVER AREA	NO INFORMATION PROVIDED	
3/19/2013	✓	✓	2PM		3/11/2013	7PM	3/11/2013	65TH AVENUE	MANHOLE	DITCH TO SOWASHEE CREEK	3,000	EXCESSIVE RAINFALL - 1.5 INCHES	COLLECTED DEBRIS AND SPREAD LIME OVER AREA	NO INFORMATION PROVIDED	
3/19/2013	✓	✓	2PM		3/11/2013	8PM	3/12/2013	HWY 45 NORTH, EAST MERIDIAN WWTP	MANHOLE	SOWASHEE CREEK	9,000	EXCESSIVE RAINFALL - 1.5 INCHES	COLLECTED DEBRIS AND SPREAD LIME OVER AREA	NO INFORMATION PROVIDED	
3/21/2013	✓	✓	6PM		2/17/2013	10AM	2/18/2013	100 TO 65TH AVENUE	MANHOLE	SOWASHEE CREEK	10,000	EXCESSIVE RAINFALL - 8 INCHES THE WEEK PRIOR, PIPE RESTRICTION DUE TO JOINT FAILURE ALLOWING DIRT INTO SEWER LINE	REPAIRED AND WASHED LINE, COLLECTED DEBRIS AND SPREAD LIME OVER AREA	LINE REPAIRED AND WASHED	
3/21/2013	✓	✓	10PM		3/18/2013	11AM	3/19/2013	CHIP PICKERING DRIVE	PRESSURE LINE	SOWASHEE CREEK	177,000	BREAK IN LINE	SHUT OFF PUMP STATION	REPAIRED LINE	
3/21/2013	✓	✓	9AM		3/18/2013	6PM	3/19/2013	HWY 45 NORTH, EAST MERIDIAN WWTP ACCESS ROAD	MANHOLE	SOWASHEE CREEK	3,800	INFLOW & PIPE RESTRICTION	JETTED LINE TO ALLOW MORE FLOW THROUGH LINE, COLLECTED DEBRIS AND SPREAD LIME OVER AREA	NO INFORMATION PROVIDED	
3/21/2013	✓	✓	X		3/19/2013	1PM	3/19/2013	34TH & 10TH AVENUE	LINE	SOWASHEE CREEK	60,000	BANK COLLAPSED SHIFTING THE LINE, WHICH CAUSED THE RUBBERS IN PIPE JOINTS TO PUSH OUT	REPAIRED LINE	REPAIRED LINE	
3/29/2013	✓	✓	3PM		3/24/2013	4:30PM	3/24/2013	4524 HWY 39 NORTH	MANHOLE	SOWASHEE CREEK	180	GREASE BLOCKAGE	JETTED LINE, COLLECTED DEBRIS AND SPREAD LIME OVER AREA	NO INFORMATION PROVIDED	
3/29/2013	✓	✓	11:30AM		3/24/2013	2PM	3/27/2013	HWY 45 NORTH, EAST MERIDIAN WWTP ACCESS ROAD	MANHOLE	SOWASHEE CREEK	8,940	I&I, PIPE RESTRICTION	COLLECTED DEBRIS	NO INFORMATION PROVIDED	
5/1/2013	✓	✓	7AM		5/1/2013	X	X	EAST MERIDIAN WWTP, HWY 45 NORTH, EAST MERIDIAN WWTP ACCESS ROAD	MANHOLE	SOWASHEE CREEK	55,000	EXCESSIVE RAINFALL - 1.5 INCHES	REMOVE DEBRIS AND SPREAD LIME OVER AREA	NO INFORMATION PROVIDED	
5/13/2013	✓	✓	7:30AM		5/10/2013	12PM	5/11/2013	HWY 11/80 EAST AT CRACKER BARREL	MANHOLE	SOWASHEE CREEK	60,000	EXCESSIVE RAINFALL - 2 INCHES	REMOVE DEBRIS AND SPREAD LIME OVER AREA	NO INFORMATION PROVIDED	
5/13/2013		✓	7:30AM		5/10/2013	12PM	5/11/2013	EAST MERIDIAN WWTP, HWY 45 NORTH, EAST MERIDIAN WWTP ACCESS ROAD	MANHOLE	SOWASHEE CREEK	75,000	EXCESSIVE RAIN - 2 INCHES	LIME AREA	NO INFORMATION PROVIDED	
6/18/2013			9AM		3/25/2013	10AM	3/25/2013	27TH STREET AND 45TH AVENUE	PUMP STATION	SOWASHEE CREEK	4,500	PUMP FAILURE	STATION BROUGHT BACK ONLINE BY CITY PERSONNEL	REPLACED CONTROLLER PANEL AT STATION	
6/18/2013			9AM		6/17/2013	11AM	6/17/2013	CHIP PICKERING DRIVE	LINE	SOWASHEE CREEK	147,000	BLOWOUT IN PRESSURE LINE	REPAIRED LINE	REPAIR OF LINE	
7/10/2013	✓		9:30AM		5/13/2013	1:30AM	5/17/2013	29TH AVENUE & SOWASHEE CREEK	24" SEWER LINE	SOWASHEE CREEK	120,000	BLOCKAGE IN LINE	REPAIR SEWER LINE, FLUSHED LINE AND CLEANED UP DEBRIS, LIME PUT DOWN OVER AREA	AT THIS TIME, CITY LOOKING TO REPLACE ABOUT 200' OF 24" SEWER LINE	SSO REPORT TO DEQ INCLUDED ATTACHMENT
8/15/2013	✓	✓	12AM		8/13/2013	10:30AM	8/14/2013	HWY 11/80 EAST AT CRACKER BARREL	MANHOLE	SOWASHEE CREEK	10,500	EXCESSIVE RAINFALL - 4 INCHES	COLLECTED DEBRIS AND SPREAD LIME OVER AREA	NO INFORMATION PROVIDED	
8/15/2013	✓	✓	12AM		8/13/2013	9AM	8/14/2013	HWY 45 NORTH, EAST MERIDIAN WWTP	MANHOLE	SOWASHEE CREEK	13,200	EXCESSIVE RAINFALL - 4 INCHES	COLLECTED DEBRIS AND SPREAD LIME OVER AREA	NO INFORMATION PROVIDED	
10/7/2013	✓		10PM		10/3/2013	9AM	10/4/2013	COTTON GIN ROAD	PUMP STATION	DITCH TO SOWASHEE CREEK	10,000	PUMP FAILURE	COLLECTED DEBRIS AND DISINFECTED AREA	REPAIRED PUMP	
11/13/2013	✓		11PM		11/4/2013	1PM	11/5/2013	CHIP PICKERING DRIVE	PRESSURE LINE	SOWASHEE CREEK	262,000	BREAK IN SEWER LINE	SPOT REPAIR OF LINE, COLLECTED DEBRIS AND DISINFECTED AREA	LINE REPAIRED	
11/13/2013	✓		X		11/9/2013	2:45PM	11/12/2013	CHIP PICKERING DRIVE	PRESSURE LINE	SOWASHEE CREEK	968,000	BREAK IN LINE	SPOT REPAIR OF LINE, COLLECTED DEBRIS AND DISINFECTED AREA	LINE REPAIRED	

Date SSO Event Report Received by MDEQ	SSO Reporting		City Notified of SSO Event			SSO Ceased		Location of SSO		Ultimate Destination of SSO	Volume of SSO, (gal) (approx.)	Cause of SSO	Corrective Actions to Stop SSO	Corrective Action to Prevent Future SSOs	Miscellaneous Information
	City of Meridian Excel Matrix	MDEQ Excel Matrix	Time		Date	Time	Date	Location	Source						
1/13/2014	✓		9AM		1/9/2014	2:15PM	1/9/2014	CHIP PICKERING DRIVE	PRESSURE LINE	SOWASHEE CREEK	132,000	BLOWOUT IN PRESSURE LINE	SPOT REPAIR ON LINE	LINE REPAIRED	
1/21/2014	✓		8AM		1/17/2014	12NOON	1/17/2014	CHIP PICKERING DRIVE	PRESSURE LINE	SOWASHEE CREEK	127,000	BLOWOUT IN PRESSURE LINE	SPOT REPAIR ON LINE	LINE REPAIRED	
1/28/2014	✓		2AM		1/27/2014	2PM	1/27/2014	CHIP PICKERING DRIVE	PRESSURE LINE	SOWASHEE CREEK	145,000	BLOWOUT IN PRESSURE LINE	SPOT REPAIR ON LINE	LINE REPAIRED	
2/4/2014	✓		8AM		1/30/2014	2PM	1/30/2014	CHIP PICKERING DRIVE	PRESSURE LINE	SOWASHEE CREEK	130,000	BLOWOUT IN PRESSURE LINE	SPOT REPAIR ON LINE	LINE REPAIRED	
2/5/2014	✓		10PM		2/5/2014	12:30PM	2/5/2014	HWY 11/80 EAST AT CRACKER BARREL	MANHOLE	SOWASHEE CREEK	30-35 GALS	EXCESSIVE RAIN - 1.5 INCHES	COLLECTED DEBRIS AND SPREAD LIME OVER AREA	NO INFORMATION PROVIDED	
2/5/2014	✓		10PM		2/4/2014	12:30PM	2/5/2014	HWY 45 NORTH, EAST MERIDIAN WWTP	MANHOLE	SOWASHEE CREEK	40-50 GPM	EXCESSIVE RAIN - 1.5 INCHES	COLLECTED DEBRIS AND SPREAD LIME OVER AREA	NO INFORMATION PROVIDED	
2/13/2014	✓		7AM		2/10/2014	2PM	2/10/2014	CHIP PICKERING DRIVE	PRESSURE LINE	SOWASHEE CREEK	140,000	BREAK IN LINE	SPOT REPAIR	LINE REPAIRED	
2/18/2014	✓		2:30PM		2/15/2014	8PM	2/15/2014	CHIP PICKERING DRIVE	PRESSURE LINE	SOWASHEE CREEK	125,000	BREAK IN LINE	SPOT REPAIR	LINE REPAIRED	
3/4/2014	✓		5AM		2/21/2014	3PM	2/21/2014	CHIP PICKERING DRIVE	PRESSURE LINE	SOWASHEE CREEK	147,000	BREAK IN LINE	SPOT REPAIR	LINE REPAIRED	
3/14/2014	✓		7AM		3/10/2014	1:30PM	3/10/2014	CHIP PICKERING DRIVE	PRESSURE LINE	SOWASHEE CREEK	138,000	BREAK IN LINE	SPOT REPAIR	LINE REPAIRED	
3/28/2014	✓		12AM		2/28/2014	ONGOING	ONGOING	HWY 11/80 EAST AT CRACKER BARREL	MANHOLE	SOWASHEE CREEK	45 GPM	EXCESSIVE RAINFALL - 1.5 INCHES	COLLECTED DEBRIS AND DISINFECTED AREA	NO INFORMATION PROVIDED	
3/28/2014	✓		12AM		3/28/2014	ONGOING	ONGOING	SOWASHEE STREET	MANHOLE	SOWASHEE CREEK	30-35 GPM	EXCESSIVE RAINFALL - 1.5 INCHES	COLLECTED DEBRIS AND DISINFECTED AREA	NO INFORMATION PROVIDED	
3/28/2014	✓		12AM		3/28/2014	ONGOING	ONGOING	HWY 45 NORTH, EAST MERIDIAN WWTP	MANHOLE	SOWASHEE CREEK	60,000	EXCESSIVE RAINFALL - 1.5 INCHES	COLLECTED DEBRIS AND DISINFECTED AREA	NO INFORMATION PROVIDED	
4/8/2014	✓		5PM		4/13/2014	3PM	4/15/2014	HWY 11/80 EAST, BEHIND STRIBLING EQUIPMENT	MANHOLE	SOWASHEE CREEK	408,000	EXCESSIVE RAINFALL - 5 INCHES	COLLECTED DEBRIS AND DISINFECTED AREA	NO INFORMATION PROVIDED	
4/8/2014	✓		8PM		4/4/2014	10PM	4/8/2014	HWY 11/80 EAST, BEHIND STRIBLING EQUIPMENT	MANHOLE	SOWASHEE CREEK	200 GPM	EXCESSIVE RAINFALL - 6 INCHES	COLLECTED DEBRIS AND DISINFECTED AREA	NO INFORMATION PROVIDED	
4/22/2014	✓		6PM		4/13/2014	2PM	4/16/2014	HWY 45 NORTH, EAST MERIDIAN WWTP	MANHOLE	SOWASHEE CREEK	365,000	EXCESSIVE RAINFALL - 4 INCHES	COLLECTED DEBRIS AND DISINFECTED AREA	NO INFORMATION PROVIDED	
4/22/2014	✓		8PM		4/4/2014	7PM	4/9/2014	HWY 45 NORTH, EAST WWTP ENTRANCE	MANHOLE	SOWASHEE CREEK	535,000	EXCESSIVE RAINFALL - 4 INCHES	COLLECTED DEBRIS AND DISINFECTED AREA	NO INFORMATION PROVIDED	
					4/8/2014			SOWASHEE STREET	MANHOLE	SOWASHEE CREEK					
4/22/2014	✓		3PM		4/13/2014	2PM	4/15/2014	HWY 11/80 EAST AT CRACKER BARREL	MANHOLE	SOWASHEE CREEK	211,500	EXCESSIVE RAINFALL - 4 INCHES	COLLECTED DEBRIS AND DISINFECTED AREA	NO INFORMATION PROVIDED	
4/22/2014	✓		8PM		4/4/2014	6PM	4/7/2014	HWY 11/80 EAST AT CRACKER BARREL	MANHOLE	SOWASHEE CREEK	315,000	EXCESSIVE RAINFALL - 4 INCHES	COLLECTED DEBRIS AND DISINFECTED AREA	NO INFORMATION PROVIDED	

Address	City	State	Number	
HAMILTON AVENUE	Meridian	MS	1	HAMILTON AVENUE WEST OF 29TH AVENUE & NORTH OF ST. PAUL STREET, IN
3200 saint paul st	Meridian	MS	2	THE WOODS
1616 sowashee st	Meridian	MS	3	SOWASHEE STREET
HAMILTON AVENUE	Meridian	MS	4	HAMILTON AVENUE
HAMILTON AVENUE	Meridian	MS	5	HAMILTON AVENUE
FRED CLAYTON ROAD	Meridian	MS	6	FRED CLAYTON ROAD
4001 NEWELL ROAD	Meridian	MS	7	4001 NEWELL ROAD
1616 sowashee st	Meridian	MS	8	SOWASHEE STREET
1996 hwy 45 north	Meridian	MS	9	HWY 45 & HWY 39
1616 sowashee st	Meridian	MS	10	SOWASHEE STREET SOWASHEE STREET (BEHIND
1616 sowashee st	Meridian	MS	11	MISSISSIPPI MUSIC) 26TH STREET/2606 EDGEWOOD
2606 edgewood dr	Meridian	MS	12	DRIVE
3900 OLD HWY 45 N.	Meridian	MS	13	3900 OLD HWY 45 N. HILLCREST DRIVE/BROADHEAD
2277 hillcrest drive	Meridian	MS	14	PROPERTY
2001 Hwy 39	Meridian	MS	15	HYUNDAI HWY 39
SHUMATE ROAD	Meridian	MS	16	SHUMATE ROAD
1616 sowashee st	Meridian	MS	17	SOWASHEE STREET HWY 11/80 & RUSSELL DRIVE ON
125 hwy 11	Meridian	MS	18	8 INCH LINE THAT CONNECTS TO A 24 INCH LINE, BEHIND STRIBLING EQUIPMENT
118 US 11	Meridian	MS	19	HWY 11/80 AT CRACKER BARREL
3900 OLD HWY 45 S.	Meridian	MS	20	3900 OLD HWY 45 S. HWY 11/80 AT STRIBLING
118 US 11	Meridian	MS	21	EQUIPMENT
15th place	Meridian	MS	22	15TH PLACE
118 US 11	Meridian	MS	23	HWY 11/80 CRACKER BARREL
1616 sowashee st	Meridian	MS	24	SOWASHEE STREET
4605 royal rd	Meridian	MS	25	56TH AVENUE @ ROYAL ROAD
7100 old 8th st rd	Meridian	MS	26	OLD 8TH STREET & 70TH PLACE 29TH AVENUE, SOUTH BANK, APPROXIMATELY 200 YARDS WEST OF 29TH AVENUE
3008 railroad st	Meridian	MS	27	BRIDGE/RR
3008 railroad st	Meridian	MS	28	29TH AVENUE @ RR
118 US 11	Meridian	MS	29	11/80 EAST AT CRACKER BARREL
5310 OVERBROOK LANE	Meridian	MS	30	5310 OVERBROOK LANE
1616 sowashee st	Meridian	MS	31	SOWASHEE STREET HWY 11/80 EAST AT CRACKER
118 US 11	Meridian	MS	32	BARREL
3920 26th st	Meridian	MS	33	26TH STREET & 40TH AVENUE
3109 grandview ave	Meridian	MS	34	3109 GRANDVIEW AVENUE

5525 cherokee road	Meridian	MS
600 frontage r	Meridian	MS
	Meridian	MS
1616 sowashee st	Meridian	MS
118 US 11	Meridian	MS
1616 sowashee st	Meridian	MS
118 US 11	Meridian	MS
3920 hwy 11	Meridian	MS
2710 hwy 11 south	Meridian	MS
29th ave	Meridian	MS
tommy webb dr	Meridian	MS
1400 john c stennis dr	Meridian	MS
118 US 11	Meridian	MS
1616 sowashee st	Meridian	MS
3900 old hwy 45 north	Meridian	MS
118 US 11	Meridian	MS
1616 sowashee st	Meridian	MS
1616 sowashee st	Meridian	MS
3920 hwy 11	Meridian	MS
3900 old hwy 45 north	Meridian	MS
118 US 11	Meridian	MS
3200 saint paul st	Meridian	MS
3900 old hwy 45 north	Meridian	MS
1616 sowashee st	Meridian	MS
3920 hwy 11	Meridian	MS
118 US 11	Meridian	MS
chip pickering dr	Meridian	MS
101 65th ave	Meridian	MS
3920 26th st	Meridian	MS
4020 26th st	Meridian	MS
3900 old hwy 45 north	Meridian	MS
118 US 11	Meridian	MS
3920 hwy 11	Meridian	MS

35	5525 CHEROKEE ROAD
36	600 FRONTAGE ROAD
37	2900 SAINT PAUL STREET
38	SOWASHEE STREET
	HWY 11/80 EAST AT CRACKER
39	BARREL
40	SOWASHEE STREET
	HWY 11/80 EAST AT CRACKER
41	BARREL
	HWY 11/80 EAST & RUSSELL
	STREET, BEHIND STRIBLING
42	EQUIPMENT
43	HWY 11/CELOTEX
45	29TH AVENUE
46	TOMMY WEBB DRIVE
	CHIP PICKERING DRIVE AND
47	STENNIS DRIVE
	HWY 11/80 EAST AT CRACKER
49	BARREL
50	SOWASHEE STREET
	HWY 45 NORTH , EAST MERIDIAN
51	WWTP
	HWY 11/80 EAST AT CRACKER
52	BARREL
53	SOWASHEE STREET
54	SOWASHEE STREET
	HWY 11/80, BEHIND STRIBLING
55	EQUIPMENT
	HWY 45 NORTH, EAST MERIDIAN
56	WWTP
	HWY 11/80 EAST AT CRACKER
57	BARREL
58	29TH AVENUE, MULTI-COUNTY
	HWY 45 NORTH, ENTRANCE TO
59	EAST MERIDIAN WWTP
60	SOWASHEE STREET
	HWY 11/80, BEHIND STRIBLING
61	EQUIPMENT
	HWY 11/80 AT CRACKER BARREL
62	
63	CHIP PICKERING DRIVE
	65TH AVENUE (MAPLE GAS
64	TERMINAL)
65	40TH AVENUE & 26 STREET
66	26 & 41ST STREET
	HWY 45 NORTH (EAST MERIDIAN
67	WWTP ENTRANCE)
	HWY 11 & 80 AT CRACKER
68	BARREL
	HWY 11 & 80, BEHIND STRIBLING
69	EQUIPMENT

1616 sowashee st	Meridian	MS
1616 sowashee st	Meridian	MS
1200 roebuck dr	Meridian	MS
old 8th st	Meridian	MS
3920 hwy 11	Meridian	MS
118 US 11	Meridian	MS
parkway boulevard	Meridian	MS
1616 sowashee st	Meridian	MS
65th ave	Meridian	MS
3900 old hwy 45 north	Meridian	MS
chip pickering dr	Meridian	MS
3900 old hwy 45 north	Meridian	MS
1000 34th st	Meridian	MS
4524 hwy 39 north	Meridian	MS
3900 old hwy 45 north	Meridian	MS
3900 old hwy 45 north	Meridian	MS
118 US 11	Meridian	MS
3900 old hwy 45 north	Meridian	MS
4432 27th st	Meridian	MS
chip pickering dr	Meridian	MS
3 martin luther king jr dr	Meridian	MS
118 US 11	Meridian	MS
3900 old hwy 45 north	Meridian	MS
cotton gin rd	Meridian	MS
chip pickering dr	Meridian	MS
chip pickering dr	Meridian	MS
chip pickering dr	Meridian	MS
chip pickering dr	Meridian	MS
chip pickering dr	Meridian	MS
chip pickering dr	Meridian	MS
118 US 11	Meridian	MS
3900 old hwy 45 north	Meridian	MS
chip pickering dr	Meridian	MS

70	SOWASHEE STREET
71	SOWASHEE STREET
72	HWY 145 & SOWASHEE STREET
73	OLD 8TH STREET
	HWY 11/80, BEHIND STRIBLING
74	EQUIPMENT
	HWY 11/80 AT CRACKER BARREL
75	
76	PARKWAY BOULEVARD
77	SOWASHEE STREET
78	65TH AVENUE
	HWY 45 NORTH, EAST MERIDIAN
79	WWTP
81	CHIP PICKERING DRIVE
	HWY 45 NORTH, EAST MERIDIAN
	WWTP ACCESS ROAD
82	
83	34TH & 10TH AVENUE
84	4524 HWY 39 NORTH
	HWY 45 NORTH, EAST MERIDIAN
	WWTP ACCESS ROAD
85	
	EAST MERIDIAN WWTP, HWY 45
	NORTH, EAST MERIDIAN WWTP
86	ACCESS ROAD
	HWY 11/80 EAST AT CRACKER
87	BARREL
	EAST MERIDIAN WWTP, HWY 45
	NORTH, EAST MERIDIAN WWTP
88	ACCESS ROAD
	27TH STREET AND 45TH AVENUE
89	
90	CHIP PICKERING DRIVE
	29TH AVENUE & SOWASHEE
91	CREEK
	HWY 11/80 EAST AT CRACKER
92	BARREL
	HWY 45 NORTH, EAST MERIDIAN
93	WWTP
94	COTTON GIN ROAD
95	CHIP PICKERING DRIVE
96	CHIP PICKERING DRIVE
97	CHIP PICKERING DRIVE
98	CHIP PICKERING DRIVE
99	CHIP PICKERING DRIVE
100	CHIP PICKERING DRIVE
	HWY 11/80 EAST AT CRACKER
101	BARREL
	HWY 45 NORTH, EAST MERIDIAN
102	WWTP
103	CHIP PICKERING DRIVE

chip pickering dr	Meridian MS
chip pickering dr	Meridian MS
chip pickering dr	Meridian MS
118 US 11	Meridian MS
1616 sowashee st	Meridian MS
3900 old hwy 45 north	Meridian MS
3920 hwy 11	Meridian MS
3920 hwy 11	Meridian MS
3900 old hwy 45 north	Meridian MS
3900 old hwy 45 north	Meridian MS
1616 sowashee st	Meridian MS
1616 sowashee st	Meridian MS
1616 sowashee st	Meridian MS
118 US 11	Meridian MS
118 US 11	Meridian MS

104	CHIP PICKERING DRIVE
105	CHIP PICKERING DRIVE
106	CHIP PICKERING DRIVE HWY 11/80 EAST AT CRACKER
107	BARREL
108	SOWASHEE STREET HWY 45 NORTH, EAST MERIDIAN
109	WWTP HWY 11/80 EAST, BEHIND
110	STRIBLING EQUIPMENT HWY 11/80 EAST, BEHIND
111	STRIBLING EQUIPMENT HWY 45 NORTH, EAST MERIDIAN
112	WWTP HWY 45 NORTH, EAST WWTP
113	ENTRANCE
114	
115	
116	SOWASHEE STREET HWY 11/80 EAST AT CRACKER
117	BARREL HWY 11/80 EAST AT CRACKER
118	BARREL

original address	latitude	longitude
Address	City	State
HAMILTON AVENUE	Meridian	MS 32.35046 -88.6928
3200 saint paul st	Meridian	MS 32.35091 -88.7109
1616 sowashee st	Meridian	MS 32.34915 -88.6955
HAMILTON AVENUE	Meridian	MS 32.35046 -88.6928
HAMILTON AVENUE	Meridian	MS 32.35046 -88.6928
FRED CLAYTON ROAD	Meridian	MS 32.51738 -88.59
4001 NEWELL ROAD	Meridian	MS 32.39955 -88.672
1616 sowashee st	Meridian	MS 32.34915 -88.6955
1996 hwy 45 north	Meridian	MS 32.37812 -88.6803
1616 sowashee st	Meridian	MS 32.34915 -88.6955
1616 sowashee st	Meridian	MS 32.34915 -88.6955
2606 edgewood dr	Meridian	MS 32.38552 -88.7427
3900 OLD HWY 45 N.	Meridian	MS 32.39928 -88.6666
2277 hillcrest drive	Meridian	MS 32.33861 -88.6812
2001 Hwy 39	Meridian	MS 32.37876 -88.68
SHUMATE ROAD	Meridian	MS 32.41207 -88.7127
1616 sowashee st	Meridian	MS 32.34915 -88.6955
125 hwy 11	Meridian	MS 32.36954 -88.673
118 US 11	Meridian	MS 32.36938 -88.6719
3900 OLD HWY 45 S.	Meridian	MS 32.39928 -88.6666
118 US 11	Meridian	MS 32.36938 -88.6719
15th place	Meridian	MS 32.41089 -88.6934
118 US 11	Meridian	MS 32.36938 -88.6719
1616 sowashee st	Meridian	MS 32.34915 -88.6955
4605 royal rd	Meridian	MS 32.38157 -88.7247
7100 old 8th st rd	Meridian	MS 32.36855 -88.75
3008 railroad st	Meridian	MS 32.35606 -88.7086
3008 railroad st	Meridian	MS 32.35606 -88.7086
118 US 11	Meridian	MS 32.36938 -88.6719
5310 OVERBROOK LANE	Meridian	MS 32.41509 -88.6932
1616 sowashee st	Meridian	MS 32.34915 -88.6955
118 US 11	Meridian	MS 32.36938 -88.6719
3920 26th st	Meridian	MS 32.3855 -88.7181
3109 grandview ave	Meridian	MS 32.39017 -88.6931
5525 cherokee road	Meridian	MS 32.41824 -88.6948
600 frontage r	Meridian	MS 32.36131 -88.6785
2900 st paul st	Meridian	MS 32.35094 -88.7034
1616 sowashee st	Meridian	MS 32.34915 -88.6955
118 US 11	Meridian	MS 32.36938 -88.6719
1616 sowashee st	Meridian	MS 32.34915 -88.6955
118 US 11	Meridian	MS 32.36938 -88.6719
3920 hwy 11	Meridian	MS 32.36938 -88.6719
2710 hwy 11 south	Meridian	MS 32.33798 -88.7392
29th ave	Meridian	MS 32.38534 -88.7076
tommy webb dr	Meridian	MS 32.33982 -88.7348

1400 john c stennis dr	Meridian	MS	32.53501	-88.6152
118 US 11	Meridian	MS	32.36938	-88.6719
1616 sowashee st	Meridian	MS	32.34915	-88.6955
3900 old hwy 45 north	Meridian	MS	32.39928	-88.6666
118 US 11	Meridian	MS	32.36938	-88.6719
1616 sowashee st	Meridian	MS	32.34915	-88.6955
1616 sowashee st	Meridian	MS	32.34915	-88.6955
3920 hwy 11	Meridian	MS	32.36938	-88.6719
3900 old hwy 45 north	Meridian	MS	32.39928	-88.6666
118 US 11	Meridian	MS	32.36938	-88.6719
3200 saint paul st	Meridian	MS	32.35091	-88.7109
3900 old hwy 45 north	Meridian	MS	32.39928	-88.6666
1616 sowashee st	Meridian	MS	32.34915	-88.6955
3920 hwy 11	Meridian	MS	32.36938	-88.6719
118 US 11	Meridian	MS	32.36938	-88.6719
chip pickering dr	Meridian	MS	32.51877	-88.6035
101 65th ave	Meridian	MS	32.35313	-88.7463
3920 26th st	Meridian	MS	32.3855	-88.7181
4020 26th st	Meridian	MS	32.38555	-88.7195
3900 old hwy 45 north	Meridian	MS	32.39928	-88.6666
118 US 11	Meridian	MS	32.36938	-88.6719
3920 hwy 11	Meridian	MS	32.36938	-88.6719
1616 sowashee st	Meridian	MS	32.34915	-88.6955
1616 sowashee st	Meridian	MS	32.34915	-88.6955
1200 roebuck dr	Meridian	MS	32.34804	-88.6919
old 8th st	Meridian	MS	32.39547	-88.7737
3920 hwy 11	Meridian	MS	32.36938	-88.6719
118 US 11	Meridian	MS	32.36938	-88.6719
parkway boulevard	Meridian	MS	32.39257	-88.6993
1616 sowashee st	Meridian	MS	32.34915	-88.6955
65th ave	Meridian	MS	32.36151	-88.7446
3900 old hwy 45 north	Meridian	MS	32.39928	-88.6666
chip pickering dr	Meridian	MS	32.51877	-88.6035
3900 old hwy 45 north	Meridian	MS	32.39928	-88.6666
1000 34th st	Meridian	MS	32.39257	-88.6889
4524 hwy 39 north	Meridian	MS	32.40552	-88.6764
3900 old hwy 45 north	Meridian	MS	32.39928	-88.6666
3900 old hwy 45 north	Meridian	MS	32.39928	-88.6666
118 US 11	Meridian	MS	32.36938	-88.6719
3900 old hwy 45 north	Meridian	MS	32.39928	-88.6666
4432 27th st	Meridian	MS	32.38641	-88.7229
chip pickering dr	Meridian	MS	32.51877	-88.6035
3 martin luther king jr dr	Meridian	MS	32.35597	-88.7099
118 US 11	Meridian	MS	32.36938	-88.6719
3900 old hwy 45 north	Meridian	MS	32.39928	-88.6666
cotton gin rd	Meridian	MS	32.46845	-88.6202
chip pickering dr	Meridian	MS	32.51877	-88.6035

chip pickering dr	Meridian	MS	32.51877	-88.6035
chip pickering dr	Meridian	MS	32.51877	-88.6035
chip pickering dr	Meridian	MS	32.51877	-88.6035
chip pickering dr	Meridian	MS	32.51877	-88.6035
chip pickering dr	Meridian	MS	32.51877	-88.6035
118 US 11	Meridian	MS	32.36938	-88.6719
3900 old hwy 45 north	Meridian	MS	32.39928	-88.6666
chip pickering dr	Meridian	MS	32.51877	-88.6035
chip pickering dr	Meridian	MS	32.51877	-88.6035
chip pickering dr	Meridian	MS	32.51877	-88.6035
chip pickering dr	Meridian	MS	32.51877	-88.6035
118 US 11	Meridian	MS	32.36938	-88.6719
1616 sowashee st	Meridian	MS	32.34915	-88.6955
3900 old hwy 45 north	Meridian	MS	32.39928	-88.6666
3920 hwy 11	Meridian	MS	32.36938	-88.6719
3920 hwy 11	Meridian	MS	32.36938	-88.6719
3900 old hwy 45 north	Meridian	MS	32.39928	-88.6666
3900 old hwy 45 north	Meridian	MS	32.39928	-88.6666
1616 sowashee st	Meridian	MS	32.34915	-88.6955
1616 sowashee st	Meridian	MS	32.34915	-88.6955
1616 sowashee st	Meridian	MS	32.34915	-88.6955
118 US 11	Meridian	MS	32.36938	-88.6719
118 US 11	Meridian	MS	32.36938	-88.6719